





Max Frame 48" × 77' DP RATING +50/-50 IMPACT NO

Installation Notes:

- Seal flange/frame to substrate.
- minimum of 1" into the wood framing. For two (2X) wood frame substrate (min. S.G. = 0.42). Use #8 X 1 1/4" PH or greater fastener throught the nail fin with sufficient length to penetrate a
- ယ Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads project of installation. to the structure. The host structure is the responsibility of the architect or engineer of record for the

General Notes:

- Building Code (FBC) and the industry requirement for the stated conditions. the adopted International Building Code (IBC), the International Residential Code (IRC), the Florida The product shown herein is designed, tested and manufactured to comply with the wind load criteria of
- 9 2 4 All glazing shall conform to ASTM E1300
 - At minimum, glazing is single strength annealed insulated glass
- Use structural or composite shims where required

packaged with the window or go to www.jeld-wen.com. conditions. For the complete installation procedure, see the instructions not address he sealing consideration that may arise in different wall noted. It is not intended as a guide to the installation process and does window to achieve the rated design pressure up to the size limitations This schedule addresses only the fasteners required to anchor the

DISCLAIMER:

except as authorized by JELD-WEN Inc. reproduced or copied in whole or in part or used or disclosed to others This drawing and its contents are confidential and are not to be

SHEET 1 OF 1	REV: 00 SHEET	CAD DWG. No.:	TION:	PLANT NAME AND LOCATION:	IDENTIFIER NO.
					D012413
Idow	ung win	Brickmould vinyi i iic single Hung window	ickmould	<u> </u>	APPROVED BY:
	10/5-			шпе	CHECKED BY: J. Goossen
Phone: (800) 535-3936	_		عند ل	SCALE: NTS	D. Vezo
3737 Lakeport Blvd		HI DWIN		05/19/2015	PROJECT ENGINEER: