

#### WOOD FRAME SECTION (TYP) VERTICAL SECTION NOTE: Caulk between Brickmould & Wood Opening. $\odot$ 3/4" MINIMUM EDGE DISTANCE 1 1/2" MIN. EMBEDMENT 3/4" MINIMUM EDGE DISTANCE 1 1/2" MIN. EMBEDMENT -1/4" MAX SHIM SPACE 1/4" MAX SHIM SPACE

## 3/4" MINIMUM EDGE DISTANCE 1 1/2" MIN. EMBEDMENT THRU JAMB INSTALLATION

SHIM

SPACE

#### **M**a× 96 × Frame 72 /-50 IMPACT Z O

FRAME JAMB SECTION (TYP)

HORIZONTAL SECTION

NOTE: Caulk between Brickmould & Wood Opening.

## Installed Fastener Schedule:

- $\sim$   $\rightarrow$ Seal flange/frame to substrate.
- the wood framing. For 2X wood frame substrate (min. S.G. = 0.42). Use #8 PH or greater fasteners through jamb with sufficient length to penetrate a minimum of 1 1/2" into
- ယ loads to the structure. The host structure is the responsibility of the architect or engineer of record for the Host structure (wood buck, stud framing and opening) to be designed and anchored to properly transfer all project of installation.

# window to achieve the rated design pressure up to the size limitations This schedule addresses only the fasteners required to anchor the

conditions. For the complete installation procedure, see the instructions not address the sealing consideration that may arise in different wall packaged with the window or go to noted. It is not intended as a guide to the installation process and does www.jeld-wen.com/resources/installation.

### DISCLAIMER:

except as authorized by JELD-WEN Inc. reproduced or copied in whole or in part or used or disclosed to others This drawing and its contents are confidential and are not to be

IDENTIFIER No.

Bend, Oregon

Cad Dwg. No.: CustWDInsashFX Cert

REV

SHEET

 $\triangleright$ 

### General Notes:

- the adopted International Building Code (IBC), the International Residential Code (IRC), the Florida Building Code (FBC) and the industry standard requirement for the stated conditions. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of
- Buck, framing and masonry by others and is responsibility of architect or engineer of record
- ωΝ All glazing shall conform to ASTM E1300
- At minimum, glazing shall be double strength annealed insulating glass

4 0

Maximum sizes are buck sizes and do not include fin or flange.

D004805	APPROVED BY: D.STOKES	CHECKED BY: K.CAMPBELL	J.HAWKINS	PROJECT ENGINEER:
Custom Wood Insash Fixed		SCALE: NTS	06/30/2017	
		JELBWEN		
		Phone: (541) 882-345	3250 Lakeport Blvo	