

# 5.5" MAX. FROM CORNERS 15" O.C. - MAX. THRU JAMB MAX.) 6" MAX. FROM CORNERS WINDOW WIDTH (36" MAX.) TYPICAL ELEVATION WITH FASTENER SPACING



## THROUGH FRAME INSTALLATION



PR	PREMIUM ATLANTIC VINYL SH WINDOW								
	Max Frame	DP RATING	IMPACT						
	36 x 72	+65/-70	УES						
LARGE MISSILE IMPACT									

### Installation Notes:

- 1. Seal flange/frame to substrate.
- Use #10 PH or greater fastener though the jamb with sufficient length to penetrate a minimum of 1 1/2" into the wood framing. For 2X wood frame substrate (min. S.G. = 0.42).
- Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

  Addendum to NAMI

Certification No: NI011567.04-R3
Reviewed By:

Date Reviewed: 07/25/2017

This schedule addresses only the fasteners required to anchor the window to achieve the rated design pressure up to the size limitations noted. It is not intended as a guide to the installation process and does not address he sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the window or go to www.ield-wen.com/resources/installation.

#### DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.

### **General Notes:**

- The product shown herein is designed, tested and manufactured to comply with the wind load criteria
  of the adopted International Building Code(IBC), the International Residential Code(IRC), the Florida
  Building Code (FBC) including HVHZ and the industry requirement for the stated conditions.
- All glazing shall conform to ASTM E1300.
- At minimum, glazing is 3mm annealed 11mm airspace 3mm annealed 2mm PVB Interlayer by DuPont - 3mm annealed.
- 4. Use structural or composite shims where required.

PROJECT ENGINEER:	DATE: 06/30/2015	IELD WEN		J	3737 Lakeport Blvd				
D. Vezo	SCALE: NTS	عندل	TRA AA TTI.		ath Falls, OR. 97 ne: (800) 535-3				
CHECKED BY: J. Kantola	TITLE:								
APPROVED BY:	Premium Atlantic Vinyl Impact Single Hung Window								
PART/PROJECT No.: D008729									
IDENTIFIER No. NCTL210-3875-1	PLANT NAME AND LOCATED	TION:	CAD DWG. No.:	REV: 00	SHEET 1 OF 1				

'AS TESTED'