

FRAME SECTION (TYP) VERTICAL SECTION 1/4" MAX SHIM SPACE -1" MIN. EMBEDMENT - 2X WOOD FRAME MIN. DISTANCE FOR EDGE: 3/4"

MIN. DISTANCE FOR EDGE: 3/4"

NAIL FIN INSTALLATION

BUILDERS VINYL SINGLE HUNG 1" MIN. -Max Frame 36×84 2X WOOD FRAME -JAMB SECTION (TYP) HORIZONTAL SECTION NOTE: Caulk between Nailing Florage & Wood Openin DP RATING IMPACT +/-35 (G) -1/4" MAX SHIM SPACE NO

Installation Notes:

- Seal flange/frame to substrate
- 2 the wood framing. For 2X wood frame substrate (min. S.G. = 0.42). Use #8 PH or greater fastener though the nail fin with sufficient length to penetrate a minimum of 1" into
- ယ to the structure. The host structure is the responsibility of the architect or engineer of record for the Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads project of installation.

conditions. For the complete installation procedure, see the instructions not address he sealing consideration that may arise in different wall packaged with the window or go to noted. It is not intended as a guide to the installation process and does window to achieve the rated design pressure up to the size limitations This schedule addresses only the fasteners required to anchor the

DISCLAIMER:

www.jeld-wen.com/resources/installation.

except as authorized by JELD-WEN Inc. reproduced or copied in whole or in part or used or disclosed to others This drawing and its contents are confidential and are not to be

'AS TESTED'

General Notes:

— 1" MIN. EMBEDMENT

- 2X WOOD FRAME

MIN. DISTANCE FOR EDGE: 3/4"

- of the adopted International Building Code(IBC), the International Residential Code(IRC), the Florida Building Code(FBC) and the industry requirement for the stated conditions. The product shown herein is designed, tested and manufactured to comply with the wind load criteria
- All glazing shall conform to ASTM E1300.
- ωΝ At minimum, glazing shall be single strength annealed insulating glass
- Use structural or composite shims where required.
- Installation methods can be interchanged within the same opening.
- An impact protective system is required where wind bourne debris protection is mandated by local
- Maximum sizes are buck sizes and do not include fin or flange

ωĦ	□PA	-	Ą	니 우			ŀ	공
SJW2010-179-FBC	008499	•	\PPROVED BY:	J. Kantola	D. Vezo			ROJECT ENGINEER:
C PLANT NAME AND LOCATION:				ппе	NTS	SCALE:	05/13/13	DATE:
	140	JELD WEN						
CAD DWG. No.: BldrsVinyITSH								
00 REV:	3	۱ '		4				
O SHEET 1 OF 1			Builders Vinyi Tilt Single Hung		Phone: (541) 882-3451	Klamath Falls, OR. 97601	טבטס במוגבסטור טואמ	3250 Lakenort Blvd