



NAILING FIN / JAMB SCREW COMBINED INSTALLATION METHOD:

- UNIT MUST NOT BE IN DIRECT CONTACT WITH EITHER CONCRETE OR TREATED BUCK MATERIAL. IF SHIM SPACE IS LESS THAN 1/8" WRAPPING THE UNIT ON ALL 4 SIDES WITH WINDOW FLASHING TAPE IS REQUIRED AS A BARRIER BETWEEN THE UNIT AND CONCRETE OR TREATED LUMBER.

NAILING FIN:

- #8 X 1 1/4" PAN HEAD OR WAFFER HEAD SCREWS MAY BE SUBSTITUTED FOR 1 1/2" ROOFING NAILS. ROOFING NAILS MUST HAVE A MINIMUM OF 1 3/8" OF PENETRATION INTO THE BUCK. ROOFING NAILS MUST BE A MINIMUM OF 1/2" FROM EACH EDGE OF THE BUCK

JAMB SCREW:

- SECURE JAMBS WITH #8 X 3" SCREWS 6" FROM CORNERS AND MIDPOINT OF JAMB.
 - SECURE HEAD JAMB AND SILL WITH #8 X 3" SCREWS CENTERED ABOVE AND BELOW THE MEETING STILES.
 - ADD ONE ADDITIONAL SCREW MIDPOINT OF HEADJAMB.
 - SHIM AT EACH SCREW LOCATION.
 - SCREWS MUST BE A MINIMUM OF 1 INCH FROM EACH EDGE OF THE BUCK
 - SCREWS MUST HAVE A MINIMUM OF 1.250" PENETRATION INTO BUCK.

NOTES:

- FOR GENERAL SPECIFICATIONS, REFER TO DOC 00003952
- THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING & SEALING INSTRUCTIONS, REFER TO THE INSTALLATION INSTRUCTIONS.
- SHIMS
 -PLACE A SHIM WITHIN 4-6 INCHES OF EACH CORNER AND SPACE ALL OTHERS EVENLY A MAXIMUM OF 15 INCHES APART.
- IF CHEMICALLY TREATED LUMBER IS USED FOR BUCK MATERIAL, FASTENERS INTO THE BUCK MUST BE A MINIMUM OF 0.90 OX/FT² ZINC HOT DIPPED GALVANIZED OR STAINLESS STEEL TYPE 304 OR 316

THE FOLLOWING PRODUCT IS APPROVED FOR NAILING FIN / JAMB SCREW COMBINED INSTALLATION.

- ULTIMATE GLIDER 12050 OXXO

| ITEM | DWG NO | DESCRIPTION |
|------|----------|------------------------------------|
| 9 | 00096815 | OXXO GLIDER |
| 4 | ----- | #8 X 3.000 WOOD SCREW |
| 3 | ----- | WOOD BUCK BY OTHERS |
| 2 | ----- | 1 1/2 INCH GALVANIZED ROOFING NAIL |
| 1 | ----- | SHIM |

PARTS LIST

UNSPECIFIED TOLERANCES

| | |
|-----------------------------------|--------------------|
| DECIMALS: XX ±.03 XXX ±.012 | ANGLE DEG: ±.5 |
| LINEAL: +.125 -.000 | FAB LINEAL: ±NA |
| MATERIAL: NA | |

| MARVIN Windows and Doors | | RESEARCH & DEVELOPMENT WARROAD, MN, USA, (218) 386-4021 | | | |
|-----------------------------|----------------|--|---------|----------------|------------------|
| PRODUCT CATEGORY: | | ULTIMATE GLIDER | | | |
| UNIT TYPE: | | OXXO | | | |
| DWG TYPE: | | INSTALLATION FL 14378 | | | |
| CHK: | SIZE: B | CLASS: | DWG NO: | 00100210 | |
| APP: | SCALE: 1:12 | DATE: 04/18/16 | DWG BY: | BORNEMAN, SKIP | SHEET: 1 OF 1 |

NOTICE - CONFIDENTIAL INFORMATION

The information in this document is privileged and strictly confidential. The information contained herein shall be used only by Marvin Windows and Doors employees and by those agents or suppliers granted official written permission. If the reader of this document is not the intended recipient, or the employee or agent of the intended recipient, please delete this document from all data storage devices, and destroy all hard copies. Any unauthorized dissemination, distribution, copying or other use of the information contained in this document is strictly prohibited.