REVISIONS				
REV	DESCRIPTION	DATE	APPROVED	
А	REVISED ANCHOR SPACING	05/20/2021	R.L.	

EASTERN ARCHITECTURAL SYSTEMS

#### NOTES

- 1. THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING THE HVHZ.
- 2. WOOD FRAMING AND MASONRY OPENING TO BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO STRUCTURE. FRAMING AND MASONRY OPENING IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD.
- 3. WHERE SHIM OR BUCK THICKNESS IS LESS THAN 1-1/2" WINDOW UNITS MUST BE ANCHORED THROUGH THE FRAME IN ACCORDANCE WITH MANUFACTURER'S PUBLISHED INSTALLATION INSTRUCTIONS. ANCHORS SHALL BE SECURELY FASTENED DIRECTLY INTO MASONRY, CONCRETE OR OTHER STRUCTURAL SUBSTRATE MATERIAL.
- 4. WHERE WOOD BUCK THICKNESS IS 1-1/2" OR GREATER, BUCK SHALL BE SECURELY FASTENED TO MASONRY, CONCRETE OR OTHER STRUCTURAL SUBSTRATE. WINDOW UNITS MAY BE ANCHORED THROUGH FRAME TO SECURED WOOD BUCK IN ACCORDANCE WITH MANUFACTURER'S PUBLISHED INSTALLATION INSTRUCTIONS.
- 5. WHERE 1X BUCK IS NOT USED DISSIMILAR MATERIALS MUST BE SEPARATED WITH APPROVED COATING OR MEMBRANE. SELECTION OF COATING OR MEMBRANE IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD.
- 6. BUCKS SHALL EXTEND BEYOND WINDOW INTERIOR FACE SO THAT FULL FRAME SUPPORT IS PROVIDED.
- 7. FOR FIN INSTALLATION SHIM AS NEEDED. FOR FRAME INSTALLATION SHIM AS REQUIRED AT EACH ANCHOR LOCATION WITH LOAD BEARING SHIM. SHIM WHERE SPACE OF 1/16" OR GREATER OCCURS. MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4".
- 8. SHIMS SHALL BE LOCATED, APPLIED AND MADE FROM MATERIALS AND THICKNESS CAPABLE OF SUSTAINING APPLICABLE LOADS.
- 9. WIND LOAD DURATION FACTOR Cd=1.6 WAS USED FOR WOOD ANCHOR CALCULATIONS.
- 10. FRAME MATERIAL: EXTRUDED RIGID PVC.
- 11. UNITS MUST BE GLAZED PER ASTM E1300, SEE SHEET 9 FOR GLASS DETAILS.
- 12. APPROVED IMPACT PROTECTIVE SYSTEM <u>IS NOT REQUIRED</u> FOR THIS PRODUCT IN WIND BORNE DEBRIS REGIONS.
- 13. FOR FIN INSTALLATION INTO WOOD FRAMING OR 2X BUCK USE #10 WOOD SCREWS WITH SUFFICIENT LENGTH TO ACHIEVE A 1 1/2" MINIMUM EMBEDMENT INTO SUBSTRATE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.

- 14. FOR FRAME ANCHORING INTO WOOD FRAMING OR 2X BUCK USE #10 WOOD SCREWS WITH SUFFICIENT LENGTH TO ACHIEVE A 1 1/4" MINIMUM EMBEDMENT INTO SUBSTRATE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 15. FOR FRAME ANCHORING INTO MASONRY/CONCRETE USE 1/4" TAPCONS WITH SUFFICIENT LENGTH TO ACHIEVE A 1 1/4" MINIMUM EMBEDMENT INTO SUBSTRATE WITH 2" MINIMUM EDGE DISTANCE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 16. FOR FRAME ANCHORING INTO METAL STRUCTURE USE #10 SMS OR SELF DRILLING SCREWS WITH SUFFICIENT LENGTH TO ACHIEVE 3 THREADS MINIMUM BEYOND STRUCTURE INTERIOR WALL. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 17. ALL FASTENERS TO BE CORROSION RESISTANT.
- 18. INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BELOW:

  A. WOOD MINIMUM SPECIFIC GRAVITY OF G=0.42
  - B. CONCRETE MINIMUM COMPRESSIVE STRENGTH OF 3,192 PSI.
  - C. MASONRY STRENGTH CONFORMANCE TO ASTM C-90, GRADE N, TYPE 1 (OR GREATER).
- D. METAL STRUCTURE: STEEL 18GA, 33KSI OR ALUMINUM 6063-T5 .125" THICK MINIMUM
- 19. UNITS MAY BE INSTALLED WITH OR WITHOUT FLANGE, OUTSIDE THE HVHZ.
- 20. APPROVED CONFIGURATIONS: XO, OX.


SIGNED: 04/06/2022

				AND VINYL	FORT MYERS, FL 33912 800-432-2204		
TABLE OF CONTENTS			SERIES 176 HR PVB VINYL HORIZONTAL SLIDING				
SHEET NO.	DESCRIPTION		WINDOW 73" X 62" NOTES				
1	NOTES	DRAWN:	DRAWN: DWG NO. REV		REV		
2	ELEVATIONS	A.R.	A.R. 08-03657		Α		
3	HORIZONTAL CROSS SECTIONS	SCALE NTS	SCALE NTS DATE 01/07/21 SHEET 1 OF 9				
4 - 8	INSTALLATION DETAILS		L. ROBERTO LOMAS P.E. 400 S. PALM AVE, INDIALANTIC, FL 32903 434-688-0609 rllomas@lrlomaspe.com				
9	COMPONENTS AND GLAZING DETAIL						



Luis R. Lomas P.E. FL No.: 62514





DESIGN PRESSURE RATING	IMPACT RATING		
±60.0PSF	LARGE MISSILE IMPACT		

MISSILE LEVEL D, WIND ZONE 4 AND HVHZ

- 1. SASH SIZE: 36 1/8" X 59 3/8"
- 2. SASH D.L.O.: 32 3/4" X 55 7/8"
- 3. FIXED D.L.O.: 32 3/4" X 57 3/16"
- 4. (2) WEEPS WITH COVER (97-03) AT SILL FACE 2" FROM EACH CORNER.
- 5. (2) 1 1/2" X 1/4" WEEP SLOT AT SILL FACE 2" FROM EACH CORNER.
- 6. (2) 1/2" X 1/8" WEEP SLOT AT SILL BEHIND GLAZING LEG.

## HARDWARE SCHEDULE (2) ASHLAND DUAL KEEPERS (13999) AT FIXED MEETING STILE 8" FROM HEAD & SILL (2) ASHLAND DUAL LOCKS (D2100AL/R) AT SASH LOCK STILE 8" FROM SASH CORNERS (2) ROLLER HOUSINGS AT EACH CORNER OF SASH BOTTOM RAILS.


FINLESS INSTALLATION

(2) TRACKS AT OPERABLE SASH HEAD & SILL

(1) ALUMINUM REINFORCEMENT (55556) IN FIXED MEETING RAIL

(5) ALUMINUM REINFORCEMENT (55557) IN SASH TOP AND BOTTOM RAILS, JAMB STILES AND SASH LOCK RAIL


SIGNED: 04/06/2022 EASTERN ARCHITECTURAL SYSTEMS




SCALE NTS SHEET 2 OF 9 DATE 01/07/21 L. ROBERTO LOMAS P.E.


FIN INSTALLATION

400 S. PALM AVE, INDIALANTIC, FL 32903 434-688-0609 rllomas@lrlomaspe.com





FL No.: 62514






FINLESS INSTALLATION











	REVISIONS				
REV	DESCRIPTION	DATE	APPROVED		
А	REVISED ANCHOR SPACING	05/20/2021	R.L.		



VERTICAL CROSS SECTION
WOOD FRAMING OR 2X BUCK INSTALLATION


NOTES:
1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS,
NOT SHOWN FOR CLARITY.
2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE
DESIGNED IN ACCORDANCE WITH ASTM E2112




WOOD FRAMING OR 2X BUCK INSTALLATION















NOTES:

1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS,

NOT SHOWN FOR CLARITY.

2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112





### NOTES:


1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY. 2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE


DESIGNED IN ACCORDANCE WITH ASTM E2112

SIGNED: 04/06/2022




CONCRETE/MASONRY W/1X BUCK INSTALLATION







VERTICAL CROSS SECTION
CONCRETE/MASONRY W/1X BUCK INSTALLATION

REVISIONS				
REV	DESCRIPTION	DATE	APPROVED	
А	REVISED ANCHOR SPACING	05/20/2021	R.L.	





VERTICAL CROSS SECTION CONCRETE/MASONRY INSTALLATION




NOTES:


1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY. 2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112






	REVISIONS				
REV	DESCRIPTION	DATE	APPROVED		
А	REVISED ANCHOR SPACING	05/20/2021	R.L.		







# JAMB INSTALLATION DETAIL WOOD FRAMING OR 2X BUCK INSTALLATION


#### NOTES:


1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.

2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112





	REVISIONS				
REV	DESCRIPTION	DATE	APPROVED		
А	REVISED ANCHOR SPACING	05/20/2021	R.L.		






EXTRUDED RIGID PVC





BOTTOM RAIL (5539) EXTRUDED RIGID PVC

LOCK RAIL (4720) EXTRUDED RIGID PVC



EXTRUDED RIGID PVC



