

**APPENDIX 1: ATTACHMENT REQUIREMENTS FOR WIND UPLIFT RESISTANCE**

TABLE	DECK	APPLICATION	TYPE	DESCRIPTION	PAGE
<a href="#">1A</a>	Wood	New or Reroof (Tear-Off)	A-1	Bonded Insulation, Bonded Roof Cover	3
<a href="#">1B</a>	Wood	New or Reroof (Tear-Off)	B-3	Mechanically Attached Anchor Sheet, Bonded Insulation, Bonded Roof Cover	3
<a href="#">1C</a>	Wood	New, Reroof (Tear-Off) or Recover	B-3	Mechanically Attached Anchor Sheet, Bonded Insulation, Bonded Roof Cover	4
<a href="#">1D</a>	Wood	New, Reroof (Tear-Off) or Recover	C-1	Mechanically Attached Insulation, Bonded Roof Cover	5
<a href="#">1E</a>	Wood	New, Reroof (Tear-Off) or Recover	D-2	Insulated, Mechanically Attached Base Sheet, Bonded Roof Cover	6
<a href="#">1F</a>	Wood	New or Reroof (Tear-Off)	E-2	Non-Insulated, Mechanically Attached Base Sheet (nails), Bonded Roof Cover	6
<a href="#">1G</a>	Wood	New, Reroof (Tear-Off) or Recover	E-2	Non-Insulated, Mechanically Attached Base Sheet (screws & plates), Bonded Roof Cover	7
<a href="#">1H</a>	Wood	New or Reroof (Tear-Off)	F	Non-Insulated, Bonded Roof Cover	8

**The following notes apply to the systems outlined herein:**

- The roof system evaluation herein pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
- Unless otherwise noted, fasteners and stress plates shall be as follows. Fastener shall be of sufficient length for the following engagements:

FASTENER/PLATE OPTIONS				
DECK TYPE	By	FBC	PARTS	MINIMUM ENGAGEMENT
Wood	Altenloh, Brinck and Co. U.S., Inc.	FL4500	Trufast #14 HD with Trufast 3" Metal Insulation Plate	Minimum ¾-inch plywood penetration or minimum 1-inch wood plank embedment
	OMG, Inc.	FL699	OMG #14 Heavy Duty with OMG 3 in. Round Metal Plate	
			OMG #14 Roofgrip with OMG Accutrac Flat Bottom	
	SFS Group USA, Inc.	FL20311	Dekfast DF-#14-PH3 with Dekfast PLT-H-2-7/8 or Dekfast PLT-R-3	

- Unless otherwise noted, insulation may be any one layer or combination of FBC Approved (Local or Statewide) board(s) that meet FBC 1505 and, for foam plastic, FBC Chapter 26, when installed with the roof cover.
- RESERVED
- Preliminary insulation attachment: Unless otherwise noted, use FBC Approved roofing fasteners and plates and refer to Section 2.2.10.1.3 of [FM Loss Prevention Data Sheet 1-29](#).
- Unless otherwise noted, insulation adhesive application rates are as follows.
  - ✓ Ribbon or bead width is at the time of application; the ribbons/beads shall expand as noted in the manufacturer's published instructions.
  - ✓ When multiple layers(s) of insulation and/or coverboard are installed in ribbon-applied adhesive, board joints shall be staggered.
  - ✓ The maximum edge distance from the adhesive ribbon to the edge of the insulation board shall be not less than one-half the specified ribbons spacing.

INSULATION ADHESIVE REFERENCES				
By	FBC	ADHESIVE	REFERENCE	MINIMUM RATE
Dupont de Nemours	FL720	INSTA STIK Quik Set Insulation Adhesive	INSTA STIK	Continuous 0.75 to 1-inch wide ribbons, 12-inch o.c.
H.B. Fuller Company	FL1800	Millennium One Step Foamable Adhesive	M-OSFA	Continuous 0.25 to 0.5-inch wide ribbons, 12-inch o.c.
ICP Construction, Inc.	FL1365	Polyset Commercial Roofing Adhesive	Polyset CRA	Continuous 2.5 to 3-inch wide ribbons, 12-inch o.c.
OMG, Inc.	FL1608	OlyBond 500 Adhesive Fastener	OB500	Continuous 0.75-inch wide ribbons, 12-inch o.c. (PaceCart, SpotShot or Canister)
Generic, ASTM D312, Type IV	N/A	hot asphalt		Full coverage at 25-30 lbs/square

- 7 Unless otherwise noted, all insulations are flat-stock or taper board of the minimum thickness noted. Tapered polyisocyanurate at the following thickness limitations may be substituted with the following Maximum Design Pressure (MDP) limitations. In no case shall these values be used to 'increase' the MDP listings in the tables; rather if MDP listing below meets or exceeds that listed for a particular system in the tables, then the thinner board listed below may be used as a drop-in for the equivalent thicker material listed in the table.

MDP LIMITATIONS FOR TAPERED POLYISOCYANURATE INSULATIONS				
ADHESIVE	INSULATION		MIN. TAPERED THICKNESS (IN)	MDP (psf)
	LISTED PRODUCT	FBC		
M-OSFA	Any polyisocyanurate listed with adhesive herein	Various	0.5	-157.5
Polyset CRA	Any polyisocyanurate listed with adhesive herein	Various	1.0	-117.5
OB500	Rmax Multi-Max FA3	FL11207	0.5	-45.0
OB500	Hunter H-Shield	FL5968	0.5	-315.0
OB500	Johns Manville ENRGY 3	FL4205	0.5	-315.0
OB500	Atlas ACFoam II	FL17989	0.5	-487.5

- 8 For adhered roof insulation and board-size: Unless otherwise noted, refer to Section 2.2.10.6.2 of [FM Loss Prevention Data Sheet](#) 1-29.
- 9 For mechanically attached components or partially-bonded insulation, the maximum design pressure for the selected assembly shall meet or exceed at least the Zone 1 PRIME design pressure determined in accordance with FBC Chapter 16. Elevated pressure zones shall employ an attachment density designed by a qualified design professional to resist the elevated pressure criteria. Commonly used methods are [ANSI/SPRI WD1](#), [FM Loss Prevention Data Sheet](#) 1-29, [Roofing Application Standard](#) RAS 117 and RAS 137. Assemblies marked with an asterisk\* carry the limitations set forth in Section 2.2.10.1 of [FM Loss Prevention Data Sheet](#) 1-29 for Zone 2/3 enhancements.
- 10 For assemblies with all components fully bonded, the maximum design pressure for the selected assembly shall meet or exceed critical design pressure determined in accordance with FBC Chapter 16. No rational analysis is permitted for these systems.
- 11 For mechanically attached components over existing decks, fasteners shall be tested in the existing deck for withdrawal resistance. A qualified design professional shall review the data for comparison to the minimum requirements for the system. Testing and analysis shall be in accordance with [ANSI/SPRI FX-1](#) or [Testing Application Standard](#) TAS 105. For systems using Trufast Versa-Fast, the number of Versa-Fast Fasteners installed through the Versa-Fast Plate may be increased from the minimum noted in order to yield minimum required withdrawal resistance.
- 12 For bonded insulation or membrane over existing substrates in a re-roof (tear off), the existing deck or existing roof surface shall be examined for compatibility with the adhesive to be installed. If any surface conditions exist that bring system performance into question, field uplift testing shall be conducted on mock-ups of the proposed new roof assembly. For bonded insulation or membrane over existing substrates in a recover installation, the existing roof system shall be capable of resisting project design pressures on its own merit to the satisfaction of the Authority Having Jurisdiction, as documented through field uplift testing. Field uplift testing shall be in accordance with ASTM E907, [FM Loss Prevention Data Sheet](#) 1-52 or [Testing Application Standard](#) TAS 124.
- 13 Refer to FBC 1511 for requirements and limitations regarding recover installations. For Recover Applications using System Type C-1 the base insulation layer is optional and for System Type C-2, D-1 or D-2, the insulation is optional. Alternatively, an FBC Approved insulation board or coverboard may be used as a separation layer. Board products shall be preliminarily attached prior to roof cover installation ([Note 5](#)). The separator component shall be documented as meeting FBC 1505 and, for foam plastic, FBC Chapter 26, when installed with the roof cover in Recover applications.
- 14 RESERVED
- 15 For bonded membrane applications, unless otherwise noted, refer to the following.

MEMBRANE / ADHESIVE COMBINATIONS			
REFERENCE	LAYER	MATERIAL	APPLICATION
SBS-SA	Base Ply	One or more plies DeckSeal SA Base/Ply or DeckSeal SA Base/Ply FR	Self-Adhering
	Cap Ply	DeckSeal SA SBS Cap or DeckSeal SA SBS Cap FR	

- 16 "MDP" = Maximum Design Pressure is the result of testing for wind load resistance based on allowable wind loads. Refer to FBC 1609 for determination of design wind loads ([Note 9](#) and [Note 10](#)).

**TABLE 1A: WOOD DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE A-1: BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck <a href="#">(Note 1)</a>	Base Insulation Layer		Top Insulation Layer		Roof Cover <a href="#">(Note 15)</a>			MDP (psf)
		Type	Attach <a href="#">(Notes 6,7,8)</a>	Type	Attach <a href="#">(Notes 6,7,8)</a>	Base Ply	Ply	Cap Ply	
W-1	Min. 15/32-inch APA rated CDX plywood	Min. 1.5-inch ACFoam II, ACFoam III, ENRGY-3, H-Shield, H-Shield CG, Multi-Max FA3	INSTA-STIK, M-OSFA, OB500 or Polyset CRA	(Optional) additional layer(s) of base insulation	INSTA-STIK, M-OSFA, OB500 or Polyset CRA	SBS-SA	(Optional) SBS-SA	SBS-SA	-52.5

**TABLE 1B: WOOD DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE B-3: MECHANICALLY ATTACHED ANCHOR SHEET, BONDED INSULATION, BONDED ROOF COVER**

System No.	Deck <a href="#">(Note 1)</a>	Anchor Sheet			Base Insulation		Top Insulation		Roof Cover <a href="#">(Note 15)</a>			MDP (psf)
		Type	Fasten <a href="#">(Note 11)</a>	Attach	Type	Attach <a href="#">(Notes 6,7,8)</a>	Type	Attach <a href="#">(Notes 6,7,8)</a>	Base Ply	Ply	Cap Ply	
W-2	Min. 15/32-inch APA rated CDX plywood	Polyglass “Elastobase” or “Elastobase P” with sanded-top-surface	Simplex MAXX Cap	9-inch o.c. at min. 2-inch lap and 18-inch o.c. at two, equally spaced, staggered center rows	(Optional) Min. 1.5-inch ACFoam II, ENRGY-3, H-Shield, H-Shield CG, Multi-Max FA3	Hot asphalt	Min. 0.25-inch DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board	Hot asphalt	SBS-SA	(Optional) SBS-SA	SBS-SA	-45.0*
W-3	Min. 15/32-inch APA rated CDX plywood	Polyglass “Elastobase” or “Elastobase P” with sanded-top-surface	Simplex MAXX Cap	9-inch o.c. at min. 2-inch lap and 12-inch o.c. at two, equally spaced, staggered center rows	(Optional) Min. 1.5-inch ACFoam II, ENRGY-3, H-Shield, H-Shield CG, Multi-Max FA3	Hot asphalt	Min. 0.25-inch DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board	Hot asphalt	SBS-SA	(Optional) SBS-SA	SBS-SA	-52.5
W-4	Min. 19/32-inch APA rated CDX plywood	Polyglass “Polyglass G2 Base”, “Elastobase” or “Elastobase P” with sanded-top-surface or “Elastovent”, CertainTeed “Glasbase Base Sheet”, Firestone “MB Base”, Johns Manville “Perma-Ply 28” or GAF “GAFGLAS #75 Base Sheet”	32 ga., 1-5/8-inch diameter tin caps with 11 ga. annular ring shank nails	8-inch o.c. at min. 4-inch lap and 8-inch o.c. at three (3), equally spaced, staggered center rows	(Optional) Min. 1.5-inch ACFoam II, ACFoam III, ENRGY-3, H-Shield, H-Shield CG, Multi-Max FA3	Hot asphalt	Min. 0.25-inch DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board	Hot asphalt	SBS-SA	(Optional) SBS-SA	SBS-SA	-60.0

TABLE 1B: WOOD DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)												
SYSTEM TYPE B-3: MECHANICALLY ATTACHED ANCHOR SHEET, BONDED INSULATION, BONDED ROOF COVER												
System No.	Deck <a href="#">(Note 1)</a>	Anchor Sheet			Base Insulation		Top Insulation		Roof Cover <a href="#">(Note 15)</a>			MDP (psf)
		Type	Fasten <a href="#">(Note 11)</a>	Attach	Type	Attach <a href="#">(Notes 6,7,8)</a>	Type	Attach <a href="#">(Notes 6,7,8)</a>	Base Ply	Ply	Cap Ply	
W-5	Min. 19/32-inch APA rated CDX plywood	Polyglass “Elastobase” or “Elastobase P” with sanded-top-surface	Simplex MAXX Cap Fasteners	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two (2), equally spaced, staggered center rows	(Optional) Min. 1.5-inch ACFoam II, ENRGY-3, H-Shield, H-Shield CG, Multi-Max FA3	Hot asphalt	Min. 0.25-inch DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board	Hot asphalt	SBS-SA	(Optional) SBS-SA	SBS-SA	-60.0
W-6	Min. 19/32-inch APA rated CDX plywood	Polyglass “Elastobase” or “Elastobase P” with sanded-top-surface	32 ga., 1-5/8-inch diameter tin caps with 12 ga. annular ring shank nails	6-inch o.c. at min. 4-inch lap and 6-inch o.c. at four (4), equally spaced, staggered center rows	Min. 2-inch ACFoam II, ACFoam III, H-Shield, H-Shield CG, Multi-Max FA3 or ENRGY-3	INSTA-STIK, OB500, Polyset CRA or M-OSFA, atop fastener rows, 7-inch o.c.	(Optional) Additional layers of base insulation	INSTA-STIK, OB500, Polyset CRA or M-OSFA	SBS-SA	(Optional) SBS-SA	SBS-SA	-60.0*

TABLE 1C: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER												
SYSTEM TYPE B-3: MECHANICALLY ATTACHED ANCHOR SHEET, BONDED INSULATION, BONDED ROOF COVER												
System No.	Deck <a href="#">(Note 1)</a>	Anchor Sheet			Base Insulation		Top Insulation		Roof Cover <a href="#">(Note 15)</a>			MDP (psf)
		Type	Fasten <a href="#">(Note 11)</a>	Attach	Type	Attach <a href="#">(Notes 6,7,8)</a>	Type	Attach <a href="#">(Notes 6,7,8)</a>	Base Ply	Ply	Cap Ply	
W-7	Min. 19/32-inch APA rated CDX plywood	Polyglass “Elastobase” or “Elastobase P” with sanded-top-surface or “Elastovent”	OMG #12 Roofgrip with OMG Accutrac Flat Bottom	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two (2), equally spaced, staggered center rows	(Optional) Min. 1.5-inch ACFoam II, ENRGY-3, H-Shield, H-Shield CG, Multi-Max FA3	Hot asphalt	Min. 0.25-inch DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board	Hot asphalt	SBS-SA	(Optional) SBS-SA	SBS-SA	-60.0

**TABLE 1D: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE C-1: MECHANICALLY ATTACHED INSULATION, BONDED ROOF COVER**

System No.	Deck <a href="#">(Note 1)</a>	Base Insulation Layer <a href="#">(Note 3, Note 13)</a>	Top Insulation Layer			Roof Cover <a href="#">(Note 15)</a>			MDP (psf)
			Type	Fasten <a href="#">(Note 11)</a>	Attach	Base Ply	Ply	Cap Ply	
W-8	Min. 15/32-inch APA rated CDX plywood	(Optional) One or more layers, any combination, loose laid	Min. 1.5-inch ACFoam II or H-Shield	<a href="#">Note 2</a> (#14 only)	1 per 2.7 ft <sup>2</sup>	SBS-SA	(Optional) SBS-SA	SBS-SA	-30.0
W-9	Min. 15/32-inch APA rated CDX plywood	(Optional) One or more layers, any combination, loose laid	Min. 0.25-inch DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board	<a href="#">Note 2</a> (#14 only)	1 per 2.0 ft <sup>2</sup>	SBS-SA	(Optional) SBS-SA	SBS-SA	-30.0
W-10	Min. 15/32-inch APA rated CDX plywood	One or more layers, any combination, min. 1-inch, loose laid	Min. 0.25-inch SECUROCK Gypsum-Fiber Roof Board optionally primed with Polyglass “POLYBRITE 745” or “WB3000”	<a href="#">Note 2</a> (#14 only) or OMG #14 Roofgrip with OMG 3 in. Round Metal Plate or OMG 3 in. Ribbed Galvalume Plate (Flat)	1 per 2.0 ft <sup>2</sup>	SBS-SA	None	SBS-SA	-45.0
W-11	Min. 15/32-inch APA rated CDX plywood	One or more layers, any combination, min. 1-inch, loose laid	Min. 0.25-inch DensDeck Prime optionally primed with Polyglass “POLYBRITE 745” or “WB3000”	<a href="#">Note 2</a> (#14 only) or OMG #14 Roofgrip with OMG 3 in. Round Metal Plate	1 per 2.0 ft <sup>2</sup>	SBS-SA	None	SBS-SA	-45.0
W-12	APA rated, 19/32 CAT, 0.578 in., Exposure 1 OSB or min. 19/32” APA rated plywood	(Optional) One or more layers, any combination, loose laid	Min. 1.5-inch ACFoam II, ACFoam III, EnergyGuard Polyiso Insulation, ENRGY 3, ENRGY 3 CGF, H-Shield, H-Shield CG, ISO 95+ GL, Multi-Max FA3 or Ultra-Max optionally primed with Polyglass “POLYBRITE 745” or “WB3000”	Trufast Versa Fasteners (min. ¾” penetration) & Plates; 2 screws per plate installed 180° into the holes of the plate*	1 per 1.3 ft <sup>2</sup>	SBS-SA	(Optional) SBS-SA	SBS-SA	-67.5*
	<i>Note:</i>	<i>*For re-roof or recover construction, field withdrawal resistance testing <a href="#">(Note 11)</a> shall yield minimum 180 lbf.</i>							
W-13	Min. 19/32-inch APA rated CDX plywood	(Optional) One or more layers, any combination, loose laid	Min. 1.5-inch ACFoam II, ACFoam III, EnergyGuard Polyiso Insulation, ENRGY 3, ENRGY 3 CGF, H-Shield, H-Shield CG, ISO 95+ GL, Multi-Max FA3 or Ultra-Max optionally primed with Polyglass “POLYBRITE 745” or “WB3000”	Dekfast DF-#12-PH3 with Dekfast PLT-R-3, OMG #12 Roofgrip with OMG 3 in. Galvalume Plate (non-ribbed) or OMG Accutrak Plate or Trufast #12 DP with Trufast 3” Metal Insulation Plate	1 per 1.3 ft <sup>2</sup>	SBS-SA	(Optional) SBS-SA	SBS-SA	-67.5*

**TABLE 1E: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE D-2: INSULATED, MECHANICALLY ATTACHED BASE SHEET, BONDED ROOF COVER**

System No.	Deck <a href="#">(Note 1)</a>	Insulation Layer(s) <a href="#">(Note 3, Note 13)</a>		Base Sheet			Roof Cover <a href="#">(Note 15)</a>		MDP (psf)
		Type	Attach	Type	Fasten <a href="#">(Note 11)</a>	Attach	Base Ply	Cap Ply	
W-14	Min. 19/32-inch APA rated CDX plywood	One or more layers, any combination	Prelim. Attached	DeckSeal MA NailBase	Dekfast DF-#14-PH3 with Dekfast PLT-H-2-7/8 or Trufast #14 HD with Trufast 3" Metal Insulation Plate	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two, equally spaced, staggered center rows	SBS-SA	SBS-SA	-52.5*
W-15	Min. 19/32-inch APA rated CDX plywood	One or more layers, any combination	Prelim. Attached	DeckSeal MA NailBase	OMG #12 Roofgrip with OMG Accutrac Flat Bottom	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two, equally spaced, staggered center rows	SBS-SA	SBS-SA	-60.0*
W-16	APA rated, 19/32 CAT, 0.578 in., Exposure 1 OSB or min. 19/32" APA rated plywood	One or more layers, any combination	Loose-laid	DeckSeal MA NailBase	Trufast Versa Fasteners (min. 3/4" penetration) & Plates; 2 screws per plate installed 180° into the holes of the plate, parallel to the width-direction of the sheet*	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two (2), equally spaced, staggered center rows	SBS-SA	SBS-SA	-67.5
	<i>Note: *For re-roof or recover construction, field withdrawal resistance testing <a href="#">(Note 11)</a> shall yield minimum 199 lbf.</i>								

**TABLE 1F: WOOD DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE E-2: NON-INSULATED, MECHANICALLY ATTACHED BASE SHEET (NAILS), BONDED ROOF COVER**

System No.	Deck <a href="#">(Note 1)</a>	Base Sheet			Roof Cover <a href="#">(Note 15)</a>		MDP (psf)
		Type	Fasten <a href="#">(Note 11)</a>	Attach	Base Ply	Cap Ply	
<b>NO BASE PLY:</b>							
W-17	APA rated, 7/16 CAT, 0.418 in., Exposure 1 OSB	DeckSeal MA NailBase	32 ga., 1-5/8-inch diameter tin caps with 12 ga. annular ring shank nails	6-inch o.c. at min. 3-inch lap and 6-inch o.c. at four (4), equally spaced, staggered center rows	None	SBS-SA	-45.0
W-18	Min. 15/32-inch APA rated CDX plywood	DeckSeal MA NailBase	Original Simplex Cap Nails (1-inch metal head diameter, 11 gauge x min. 1.25-inch long annular grooved shank)	6-inch o.c. at min. 3-inch lap and 6-inch o.c. at four (4), equally spaced, staggered center rows	None	SBS-SA	-52.5
W-19	APA rated, 7/16 CAT, 0.418 in., Exposure 1 OSB or min. 15/32" APA rated plywood	DeckSeal MA NailBase	Simplex MAXX Cap <i>Note: MAXX Caps are to be primed with Polyglass "PG100" or ASTM D41 primer</i>	8-inch o.c. at min. 3-inch lap and 8-inch o.c. at three (3), equally spaced, staggered center rows	None	SBS-SA	-60.0
W-20	Min. 19/32-inch APA rated CDX plywood	DeckSeal MA NailBase	32 ga., 1-5/8-inch diameter tin caps with 11 ga. annular ring shank nails	8-inch o.c. at min. 4-inch lap and 8-inch o.c. at three (3), equally spaced, staggered center rows	None	SBS-SA	-60.0
W-21	Min. 19/32-inch APA rated CDX plywood	DeckSeal MA NailBase	32 ga., 1-5/8-inch diameter tin caps with 11 ga. annular ring shank nails.	4-inch o.c. at min. 4-inch lap and 4-inch o.c. at four (4), equally spaced, staggered center rows	None	SBS-SA	-97.5
W-22	Min. 19/32-inch APA rated CDX plywood	DeckSeal MA NailBase	32 ga., 1-5/8-inch diameter tin caps with 11 ga. annular ring shank nails. <i>Note: Tin caps are to be primed with Polyglass "PG100" or ASTM D41 primer.</i>	6-inch o.c. at min. 4-inch lap and 6-inch o.c. at four (4), equally spaced, staggered center rows	None	SBS-SA	-112.5
<b>SELF-ADHERING BASE PLY:</b>							
W-23	APA rated, 7/16 CAT, 0.418 in., Exposure 1 OSB	DeckSeal MA NailBase	32 ga., 1-5/8-inch diameter tin caps with 12 ga. annular ring shank nails	6-inch o.c. at min. 3-inch lap and 6-inch o.c. at four (4), equally spaced, staggered center rows	SBS-SA	SBS-SA	-45.0

**TABLE 1F: WOOD DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE E-2: NON-INSULATED, MECHANICALLY ATTACHED BASE SHEET (NAILS), BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Sheet			Roof Cover (Note 15)		MDP (psf)
		Type	Fasten (Note 11)	Attach	Base Ply	Cap Ply	
W-24	Min. 15/32-inch APA rated CDX plywood	DeckSeal MA NailBase	Original Simplex Cap Nails (1-inch metal head diameter, 11 gauge x min. 1.25-inch long annular grooved shank)	6-inch o.c. at min. 3-inch lap and 6-inch o.c. at four (4), equally spaced, staggered center rows	SBS-SA	SBS-SA	-52.5
W-25	APA rated, 7/16 CAT, 0.418 in., Exposure 1 OSB or min. 15/32" APA rated plywood	DeckSeal MA NailBase	Simplex MAXX Cap Note: MAXX Caps are to be primed with Polyglass "PG100" or ASTM D41 primer	8-inch o.c. at min. 3-inch lap and 8-inch o.c. at three (3), equally spaced, staggered center rows	SBS-SA	SBS-SA	-60.0
W-26	Min. 19/32-inch APA rated CDX plywood	DeckSeal MA NailBase	32 ga., 1-5/8-inch diameter tin caps with 11 ga. annular ring shank nails	8-inch o.c. at min. 4-inch lap and 8-inch o.c. at three (3), equally spaced, staggered center rows	SBS-SA	SBS-SA	-60.0
W-27	Min. 19/32-inch APA rated CDX plywood	DeckSeal MA NailBase	32 ga., 1-5/8-inch diameter tin caps with 11 ga. annular ring shank nails.	4-inch o.c. at min. 4-inch lap and 4-inch o.c. at four (4), equally spaced, staggered center rows	SBS-SA	SBS-SA	-97.5

**TABLE 1G: WOOD DECKS – NEW CONSTRUCTION, REROOF (TEAR-OFF) OR RECOVER  
SYSTEM TYPE E-2: NON-INSULATED, MECHANICALLY ATTACHED BASE SHEET (SCREWS & PLATES), BONDED ROOF COVER**

System No.	Deck (Note 1)	Base Sheet			Roof Cover (Note 15)		MDP (psf)
		Type	Fasten (Note 11)	Attach	Base Ply	Cap	
<b>NO BASE PLY:</b>							
W-28	APA rated, 19/32 CAT, 0.578 in., Exposure 1 OSB or min. 19/32" APA rated plywood	DeckSeal MA NailBase	Trufast Versa Fasteners (min. 3/4" penetration) & Plates; 2 screws per plate installed 180° into the holes of the plate, parallel to the width-direction of the sheet*	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two (2), equally spaced, staggered center rows	None	SBS-SA	-67.5
	Note: *For re-roof or recover construction, field withdrawal resistance testing (Note 11) shall yield minimum 199 lbf.						
<b>SELF-ADHERING BASE PLY:</b>							
W-29	Min. 19/32-inch plywood	DeckSeal MA NailBase	Dekfast DF-#14-PH3 with Dekfast PLT-H-2-7/8 or Trufast #14 HD with Trufast 3" Metal Insulation Plate	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two (2), equally spaced, staggered center rows	SBS-SA	SBS-SA	-52.5*
W-30	Min. 19/32-inch plywood	DeckSeal MA NailBase	OMG #12 Roofgrip with OMG Accutrac Flat Bottom	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two (2), equally spaced, staggered center rows	SBS-SA	SBS-SA	-60.0*
W-31	APA rated, 19/32 CAT, 0.578 in., Exposure 1 OSB or min. 19/32" APA rated plywood	DeckSeal MA NailBase	Trufast Versa Fasteners (min. 3/4" penetration) & Plates; 2 screws per plate installed 180° into the holes of the plate, parallel to the width-direction of the sheet*	12-inch o.c. at min. 4-inch lap and 12-inch o.c. at two (2), equally spaced, staggered center rows	SBS-SA	SBS-SA	-67.5
	Note: *For re-roof or recover construction, field withdrawal resistance testing (Note 11) shall yield minimum 199 lbf.						
W-32	APA rated, 19/32 CAT, 0.578 in., Exposure 1 OSB or min. 19/32" APA rated plywood	DeckSeal MA NailBase	Trufast Versa Fasteners (min. 3/4" penetration) & Plates; 1 screws per plate in center hole* Note: Versa-Fast Plates shall be primed with Polyglass "PG100" or ASTM D41 primer.	9-inch o.c. at min. 4-inch lap and 9-inch o.c. at four (4), equally spaced center rows	SBS-SA	SBS-SA	-127.5
	Note: *For re-roof or recover construction, field withdrawal resistance testing (Note 11) shall yield minimum 141 lbf.						

**TABLE 1H: WOOD DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)  
SYSTEM TYPE F: NON-INSULATED, BONDED ROOF COVER**

System No.	Deck <a href="#">(Note 1)</a>	Primer	Roof Cover <a href="#">(Note 15)</a>				MDP (psf)
			Joint Treatment	Base Ply	Ply	Cap Ply	
<b>SELF-ADHERING BASE PLY:</b>							
W-33	Min. 15/32-inch APA rated CDX plywood	None	None	SBS-SA	(Optional) SBS-SA	SBS-SA	-90.0
W-34	Min. 15/32-inch APA rated CDX plywood	Polyglass “PG100” or ASTM D41	None	SBS-SA	(Optional) SBS-SA	SBS-SA	-97.5
W-35	Min. 15/32-inch APA rated CDX plywood	Polyglass “POLYBRITE 745” or “WB3000”	None	SBS-SA	(Optional) SBS-SA	SBS-SA	-105.0
W-36	Min. 15/32-inch APA rated CDX plywood	(Optional) Polyglass “PG100”	Plywood joints are covered with minimum 4-inch wide strips of DeckSeal SA Base/Ply, rolled into place to create continuous bond.	SBS-SA	(Optional) SBS-SA	SBS-SA	-135.0
W-37	Nominal 1-in. T&G plank, SYP decking	None	None	SBS-SA	(Optional) SBS-SA	SBS-SA	-150.0

FBC NON-HVHZ