

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave  
Indialantic, FL 32903  
434-688-0609  
rllomas@lrlomaspe.com

*FL 10181 ANSI EQ Rev A*

August 18, 2023

**To whom it may concern**

**Manufacturer:** Nan Ya Plastics Corp. USA  
8989 North Loop East  
Houston, TX 77029

**Product Approval:**  
10181.1 Gliding French Door  
10181.2 Gliding Patio Door  
10181.9 Series Nan Ya Sliding Glass Door

Letter of Equivalency of Standards


This is to verify that the products mentioned above were tested according to ANSI/AAMA/NWDA 101/I.S.2-97. I have reviewed the standard used for testing against the currently accepted standard AAMA/WDMA/CSA 101/I.S.2/A440-11. Based on my reviewing of these standards I found that the testing requirements in ANSI/AAMA/NWDA 101/I.S.2-97 are equivalent to the currently accepted standards. Therefore, these products meet the testing requirements for AAMA/WDMA/CSA 101/I.S.2/A440-11

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

Please feel free to contact me if you have any questions.

Sincerely



Luis R. Lomas P.E.  
Florida No. 62514