



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

April 4th, 2021

To: Whom It May Concern

From: Hermes F. Norero, P.E.
Registered Florida Professional Engineer #73778

FL#: FL11136

Manufacturer: JELD-WEN, inc.
3737 Lakeport Blvd.
Klamath Falls, OR. 97601

Subject: Test Standard Equivalency Statement

Dear Sir (Madam),

The below test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards and those editions referenced in the Current Florida Building Code. The manufacturer has tested their products to the following test standard edition(s):

- 1) ASTM E84-08
- 2) ASTM E1886-05
- 3) ASTM E1996-05b
- 4) ASTM E283-04

Chapter 35 of the Current Florida Building Code references the following editions of the above test standards:


- 1) ASTM E84-16
- 2) ASTM E1886-12
- 3) ASTM E1996-17
- 4) ASTM E283-04(12)

After review of the above mentioned referenced standards and editions, it has been found that the performance results and tests carried out meet the requirements for compliance with the standard editions referenced within the Current Florida Building Code. All referenced standards have been found to be equivalent.



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Respectfully,



Hermes Norero, P.E.

Florida Professional Engineer #73778

Certification of Independence: Please note that I do not have nor, will I acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor, will I acquire a financial interest in any other entity involved in the approval process of the listed product(s).