

L. Roberto Lomas P.E.

1432 Woodford Rd
Lewisville, NC 27023
434-688-0609
rllomas@lrlomaspe.com

FL 11244 ASTM EQ

October 6, 2020

Manufacturer: ProVia Door, Inc.
2150 State Route 39
Sugarcreek, OH 44681

Product Approval:

11244.3 6'8 Heritage Fiberglass Opaque IS/OS Door
11244.6 8'0 Heritage Fiberglass Opaque IS/OS Door


To whom it may concern

This is to verify that the products mentioned above were tested according to ASTM E1886-05 and ASTM E1996-05. I have reviewed the standards used for testing against the currently accepted standards ASTM E1886-12 and ASTM E1996-12. Based on my reviewing of these standards I found that the testing requirements in ASTM E1886-05, and ASTM E1996-05 are equivalent to the currently accepted standards.

Therefore, the products listed above meet the testing requirements for ASTM E1886-12 and ASTM E1996-12.

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas
FL No.: 62514
10/15/2020