



382 NE 191ST STREET #29889 • MIAMI • FLORIDA • 33179
 (954) 947-0880 • WWW.AXIOMSTRUCTURESFL.COM

**FLORIDA PRODUCT APPROVAL ADMINISTRATIVE VALIDATION
 EQUIVALENCY STATEMENT**

FL#: Per Validation Checklist
 Product/Manuf: Per Validation Checklist

Subject: Comparison of the 2020 Florida Building Code 7th Edition and the 2023 Florida Building Code 8th Edition; Chapter 35 – Referenced Standards: References to AAMA 501, ASTM E1886 and ASTM E1996.


The reference standards of AAMA 501, ASTM E1886, and ASTM E1996 in the 2017 Florida Building Code 6th Edition and 2020 Florida Building Code 7th Edition, incorporate different references. As noted in the table below, the different referenced Standard Editions are associated to each Florida Building Code version.

FBC	2020 (2017 or 2014)	2023
AAMA 501 Reference	2005	2015
ASTM E330 Reference	2002, 2014	2014
ASTM E1886 Reference	2012, 2013(a) (2005)	2013(a), 2019
ASTM E1996 Reference	2012(a), 2014(a), 2017 (2005, 2006, 2009)	2014(a), 2017, 2020

This engineer has determined that none of the changes listed above for the 2020, 2017, or 2014 FBC test protocol adoptions would negatively alter the products’ performance that are compliant with the listed 2023 FBC adopted protocols.

Respectfully Submitted,

Troy Bishop, P.E.
 #PE76131 | Cert. Auth. 31329



August 22, 2023