

Issue Date: November 14, 2018

Proposal No: Qu-00933028

Dean Boyer
Air Louvers Inc.
6285 Randolph St.
Commerce, CA 90040

Phone: 952-852-0161
Email: dboyer@activarcpg.com

Dear Mr. Boyer,

Subject: 6th Edition (2017) Florida Building Code


This letter is to confirm that the 2005 edition of ASTM E1996 "Specification for Performance of Exterior Windows, Curtain Walls, Doors and Impact Protective System Impacted by Windborne Debris in Hurricanes" as referenced in the 2017 Florida Building Code is equivalent to the 2003 edition of the standard.

If you have any questions regarding this letter report, please do not hesitate to contact the undersigned.

Sincerely,


INTERTEK TESTING SERVICES NA LTD.

Reported by:



Emma Amiralaei, EIT
Engineer, Evaluation Services

Reviewed by:



Kal Kooner, P.Eng
Director, B&C Canada

