

R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Certificate of Authorization No. 9813

October 4, 2017

To Whom It May Concern:

FL-14512 Equivalency of Standards

ASTM D 1929-91 & D 1929-96 Equivalent to ASTM D 1929-12


The products referenced in this Product Approval have been tested in accordance with ASTM D 1929-91 & D 1929-96. It has been determined by Lyndon F. Schmidt, P.E. and RW Building Consultants, Inc. that ASTM D 1929-91 & D 1929-96 are equivalent to ASTM D 1929-12, which is the reference standard and year that has been adopted by the 6th Edition (2017) Florida Building Code.

ASTM E 84-97 Equivalent to ASTM E 84-13A

The products referenced in this Product Approval have been tested in accordance with ASTM E 84-97. It has been determined by Lyndon F. Schmidt, P.E. and RW Building Consultants, Inc. that, for the purpose of this product evaluation, ASTM E 84-97 is equivalent to ASTM E 84-13A, which is the reference standard and year that has been adopted by the 6th Edition (2017) Florida Building Code.

ASTM E 1996-02 Equivalent to ASTM E 1996-05

The products referenced in this Product Approval have been tested in accordance with ASTM E 1996-02. It has been determined by Lyndon F. Schmidt, P.E. and RW Building Consultants, Inc. that ASTM E 1996-02 is equivalent to ASTM E 1996-05, which is the reference standard and year that has been adopted by the 6th Edition (2017) Florida Building Code.



Lyndon F. Schmidt, P.E.
FL No. 43409
CA No. 9813