

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave  
Indialantic, FL 32903  
434-688-0609  
rllomas@lrlomaspe.com

*FL 14604 ASTM EQ Rev A*

November 8, 2023

**Manufacturer:** Eastern Architectural Systems  
16341 Domestic Ave.  
Ft. Myers, FL 33912

**Product Approval:**

14604.3 Series 2451 Vinyl Fin Frame Impact Single Hung Window  
14604.4 Series 2451 SH Vinyl Single Hung Window w/Fin Frame - Impact  
14604.5 Series 2461 SH Vinyl Single Hung Window w/Equal Leg Frame - Impact  
14604.6 Series 2461 Vinyl Equal Leg Frame Impact Single Hung Window  
14604.7 Series FWI 1000 Impact Aluminum Single Hung Window


**To whom it may concern**

This is to verify that the products mentioned above were tested according to ASTM E1886-02, -05 and ASTM E1996-05, -06. I have reviewed the standards used for testing against the currently accepted standards ASTM E1886-19 and ASTM E1996-20. Based on my reviewing of these standards I found that the testing requirements in ASTM E1886-02, -05 and ASTM E1996-05, -06 are equivalent to the currently accepted standards.

Therefore, the products listed above meet the testing requirements for ASTM E1886-19 and ASTM E1996-20.

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas  
FL No.: 62514  
11/8/2023