

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave  
Indialantic, FL 32903  
434-688-0609  
rllomas@lrlomaspe.com

*FL 14605 AAMA EQ Rev A*

November 8, 2023

**Manufacturer:** Eastern Architectural Systems  
16341 Domestic Ave.  
Ft. Myers, FL 33912

**Product Approval:**


- 14605.1 Series "623" Vinyl Fin Frame Impact SGD
- 14605.2 Series "623" Vinyl Fin Frame or Equal Leg Impact SGD
- 14605.3 Series "623" Vinyl Fin Frame or Equal Leg SGD - NI
- 14605.4 Series "623" Vinyl Fin Frame or Equal Leg SGD - NI
- 14605.5 Series "FD-8100" Aluminum Impact Rated SGD
- 14605.6 Series "FD-8100" Aluminum Impact Rated SGD
- 14605.7 Series 135° FD8100-LMI Aluminum Impact Rated Sliding Glass Pocket Door
- 14605.8 Series "FD8100-LMI" Aluminum Impact Rated Sliding Glass Door 90° or 135°
- 14605.9 Series "90° FD8100-LMI" Aluminum Impact Rated SGD
- 14605.10 Series "FD-8100" Aluminum Impact SGD with 5'0 Panels
- 14605.11 Series "FD-8100" Aluminum Sliding Glass Pocket Door NI
- 14605.12 Series "135° FD8100" Aluminum Sliding Glass Pocket Door NI
- 14605.14 Series "FWI 6000" Aluminum Impact SGD

**To whom it may concern**

This is to verify that the products mentioned above were tested according to AAMA/WDMA/CSA 101/I.S.2/A440-05. I have reviewed the standard used for testing against the currently accepted standard AAMA/WDMA/CSA 101/I.S.2/A440-11. Based on my reviewing of these standards I found that the testing requirements in AAMA/WDMA/CSA 101/I.S.2/A440-05 are equivalent to the currently accepted standards. Therefore, these products meet the testing requirements for AAMA/WDMA/CSA 101/I.S.2/A440-11.

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas  
FL No.: 62514  
11/8/2023