

L. Roberto Lomas P.E.

208 7th Ave
Indialantic, FL 32903
434-688-0609
rllomas@lrlomaspe.com

FL 14610 AAMA EQ Rev A

November 6, 2023

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Ft. Myers, FL 33912

Product Approval:

14610.4 Series "3241" Vinyl Non-impact HS Window
14610.5 Series "4241" Vinyl Impact HS Window


To whom it may concern

This is to verify that the products mentioned above were tested according to AAMA/WDMA/CSA 101/I.S.2/A440-05. I have reviewed the standard used for testing against the currently accepted standard AAMA/WDMA/CSA 101/I.S.2/A440-11. Based on my reviewing of these standards I found that the testing requirements in AAMA/WDMA/CSA 101/I.S.2/A440-05 are equivalent to the currently accepted standards.

Therefore, these products meet the testing requirements for AAMA/WDMA/CSA 101/I.S.2/A440-11.

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas
FL No.: 62514
11/7/2023