

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave  
Indialantic, FL 32903  
434-688-0609  
rlomas@lrlomaspe.com

*FL 14610 ASTM EQ Rev A*

November 6, 2023

**Manufacturer:** Eastern Architectural Systems  
16341 Domestic Ave.  
Ft. Myers, FL 33912

**Product Approval:**  
14610.5 Series "4241" Vinyl Impact HS Window


### **To whom it may concern**

This is to verify that the products mentioned above were tested according to ASTM E1886-05 and ASTM E1996-05. I have reviewed the standards used for testing against the currently accepted standards ASTM E1886-19 and ASTM E1996-20. Based on my reviewing of these standards I found that the testing requirements in ASTM E1886-05 and ASTM E1996-05 are equivalent to the currently accepted standards.

Therefore, the products listed above meet the testing requirements for ASTM E1886-19 and ASTM E1996-20.

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas  
FL No.: 62514  
11/7/2023