

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave  
Indialantic, FL 32903  
434-688-0609  
rllomas@lrlomaspe.com

*FL 15338 ASTM EQ Rev A*

August 16, 2023

**To whom it may concern**

**Manufacturer:** LAS Enterprises  
2413 L & A Road  
Metairie, LA 70001

**Product Approval:**

15338.1 Colonial Bi-Fold Aluminum Shutter, Impact  
15338.2 Colonial Bi-Fold Aluminum Shutter, Non-Impact  
15338.3 Colonial Series B Standard Aluminum Shutter, Non-Impact  
15338.4 Colonial Standard Aluminum Shutter, Impact

Letter of Equivalency of Standards


This is to verify that the products mentioned above were tested according to ASTM E1886-05, ASTM E1996-05 and ASTM E330-02. I have reviewed these standards against the currently accepted standard ASTM E1886-19, ASTM E1996-20 and ASTM E330-14. Based on my reviewing I found that the testing requirements in ASTM E1886-05, ASTM E1996-09 and ASTM E-330-02 are equivalent to the currently accepted standards.

Therefore, these products meet the testing requirements for ASTM E1886-19, ASTM E1996-20 and ASTM E330-14.

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

Sincerely



Luis R. Lomas P.E.  
Florida No. 62514