Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2059-EER, Rev. 6 | Project No. 423-0504 | 10/16/23 | Page 1 of 3

Product Manufacturer

Natural Light Energy Systems, dba Kennedy Skylights 5294 Tower Way Sanford, FL 32773

Product Series, Model and/or Description

Curb Mounted Glass Skylights Non-Impact and Impact

Code: Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) - Equivalency of Standards

Product Testing, Materials and Certification:

- Performance Testing Standards used for this product approval:
 - o TAS 201-94 Impact Test Procedures
 - TAS 202-94 Criteria for Testing Impact; Non-impact Resistant Building Envelope Components Using Uniform Static Air Pressure
 - o TAS 203-94 Criteria for Testing Products Subject to Cyclic Wind Pressure Loading
 - o AAMA/WDMA 1600/I.S.7-00, Voluntary Specification for Skylights
- Test Reports
 - NCTL-210-3041-1,2, dated 10/5/04, signed and sealed by Gerald J. Ferrara, P.E., testing to TAS 201/202/203-94 for "ICMG" Curb Mounted Glass Skylight
 - NCTL-210-3041-3A, dated 10/5/04, signed and sealed by Gerald J. Ferrara, P.E., testing to AAMA/WDMA 1600-00/I.S.7-2000 for "CMG" Curb Mounted Glass Skylight
 - NCTL-210-3012-1, dated 4/12/04, signed and sealed by Gerald J. Ferrara, P.E., testing to AAMA/WDMA 1600-00/I.S.7-2000 for "SFG4" Curb Mounted Self Flashing Glass Skylight
- Material Certifications/Component Approvals:
 - Laminated Glass Interlayer: See current Miami-Dade Notice of Acceptance (NOA) for component approval for Kuraray Trosifol PVB Glass Interlayer by Kuraray America, Inc. used in this product. Kuraray America NOA can be found here.

Equivalency Evaluation:

PERFORMANCE TESTING

The following table shows the performance standards used in testing and those in the current edition of the FBC.

Standard Used in Testing		Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code		Comments
Description	Revision	Building Volume	Residential Volume	
	Level	(FBC)	(FRC)	
TAS 201	94	94	94	See Evaluation
TAS 202	94	94	94	Below
TAS 203	94	94	94	
AAMA/WDMA 1600/I.S.7	2000	AAMA/CSA/WDMA	AAMA/CSA/WDMA	
		101/I.S. 2/A440-	101/I.S. 2/A440-08,	
		08, 11 and 17	11 and 17	



Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2059-EER, Rev. 6 | Project No. 423-0504 | 10/16/23 | Page 2 of 3

TAS 201, TAS 202 & TAS 203: It has been concluded that no material or substantive revisions or changes to these referenced standards have occurred (where applicable) that affect the results of design, testing or engineering of the approved product(s).

AAMA/WDMA 1600/I.S.7-00, Voluntary Specification for Skylights is a voluntary standard and is not listed in the 8th Edition (2023) Florida Building Code.

AAMA/WDMA 1600/I.S.7-00 was issued when the current AAMA performance standard in use was AAMA/NWWDA 101/I.S.2-97. As AAMA/NWWDA 101/I.S.2-97 did not cover skylights, AAMA/WDMA 1600/I.S.7-00 was developed to fill that gap. AAMA standard development progressed to AAMA/WDMA 101/I.S.2/NAFS- 02 which incorporated AAMA/WDMA 1600/I.S.7-00. AAMA/WDMA 101/I.S.2/NAFS- 02 was superseded by AAMA/WDMA/ CSA 101/I.S.2/A440-05, then 08, then 11 to the current 17 recognized in the 2023 FBC.

This is detailed in Annex D of AAMA/WDMA/ CSA 101/I.S.2/ A440-17 shown below.

Annex D (informative)

Standards progression — Windows, doors and unit skylights

Note: This Annex is not a mandatory part of this Standard/Specification.

Standards progression — Windows, doors and unit skylights

Category/ Topic	AAMA/NWWDA 101/I.S.2-97 (Windows and Glass Doors) AAMA/WDMA 1600/I.S.7-2000 (Skylights) [Separate ANSI Standards]	AAMA/WDMA 101/I.S.2/NAFS- 02 (Windows, Glass Doors & Skylights) [Combined ANSI Standard]	AAMA/WDMA/ CSA 101/LS.2/ A440-05 (Windows, Doors & Skylights) [CSA format]	AAMA/WDMA/ CSA 101/I.S.2/ A440-08 (Windows, Doors & Skylights) [CSA format]	AAMA/WDMA/ CSA 101/LS.2/ A440-11 (Windows, Doors & Skylights) [CSA format]			

Product Approval Rule 61G20-3.015(2)(a) states AAMA/CSA/WDMA 101/I.S. 2/A440-05 is equivalent to AAMA/WDMA/101/I.S./NAFS-02 and AAMA/WDMA 1600/I.S. 7-00 for skylights only. AAMA/CSA/WDMA 101/I.S. 2/A440-05 is no longer referenced in Chapter 35 of the 8th Edition of the Florida Building Code.

However, as shown in the Annex D table of AAMA/WDMA/ CSA 101/I.S.2/ A440-17, AAMA/CSA/WDMA 101/I.S. 2/A440-05 is equivalent to AAMA/CSA/WDMA 101/I.S. 2/A440-08 with regard to skylights. AAMA/CSA/WDMA 101/I.S. 2/A440-08 is found in Chapter 35 of the 8th Edition of the Florida Building Code and Chapter 46 of the 8th Edition of the Florida Residential Code.

Therefore, the testing requirements of AAMA/CSA/WDMA 101/I.S. 2/A440-08, 11 and 17 have been met, thereby meeting the requirements of the 8th Edition of the Florida Building Code and the 8th Edition of the Florida Residential Code.

MATERIALS TESTING

Kuraray Trosifol PVB Glass Interlayer material properties per current Miami-Dade Notice of Acceptance (NOA) were reviewed for conformance to the current edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code and found to be acceptable. Current Kuraray America NOA can be found here.



Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2059-EER, Rev. 6 | Project No. 423-0504 | 10/16/23 | Page 3 of 3

Certificate of Independence per Product Approval Rule 61G20-3.009

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.

Evaluated By: Robert J. Amoruso, P.E. FL P.E. License Number 49752

