

August 10, 2020

Equivalence of Product Standards

Product Description:

Series SD-8700-8750, PVC Swinging Door, LM Impact, as detailed in Installation Instructions and Evaluation Report CWS-839C

Manufacturer:

Custom Window Systems, Inc. 1900 SW 44th Ave, Ocala, FL 34474

Equivalent Standards:

ASTM E 1886-02 or 05 equivalent to ASTM E 1886-13a and

ASTM E 1996-02 or 05 equivalent to ASTM E 1996-17

AAMA/WDMA/CSA-101/IS2/A440-05 equivalent to AAMA/WDMA/CSA-101/IS2/A440-08

Assessment:

The products indicated above have been tested to ASTM E 1886-02/05, ASTM E 1996-02/05, and AAMA/WDMA/CSA-101/IS2/A440-05. I have determined that for the indicated products as defined in the indicated Installation Instructions and Evaluation Report, that this product testing is equivalent to that performed for ASTM E 1886-13a, ASTM E 1996-17, and AAMA/WDMA/CSA-101/IS2/A440-08 as referenced in the 7th Edition (2020) Florida Building Code.



8/10/2020
Lucas A. Turner, P.E.
FL P.E. 58201