

Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2118-EER, Rev. 3 | Project No. 423-0305 | 9/25/23 | Page 1 of 2

Product Manufacturer

QMI
1661 Glenlake Ave.
Itasca, IL 60143

Product Name, Model and/or Description

Stormsafe Screen – Fixed Impact Screen – Non-HVHZ

Code: Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.015(4)(d) – Equivalency of Standards

Product Name, Model and/or Designation: Products covered by this evaluation include the following.

- QMI Stormsafe Screen – Fixed Impact Screen – Non-HVHZ

Product Testing, Materials and Certification:

- Test Reports by Certified Testing Laboratories, 1924 Premier Row, Orlando, FL 32809.
 - Fixed Impact Screen – Non-HVHZ: Report No. CTLA-1366W-4 to ASTM E330-02, ASTM E1886-02 and ASTM E1996-02
- Test Report by Intertek, 2658 Electronics Way, West Palm Beach, FL 33407
 - Fixed Impact Screen - HVHZ: Project/Test Report No. N3182.01-450-18-R0 to ASTM E1886-13a and ASTM E1996-17, Small Missile Impact for Porous Impact Protection Device

Performance Testing:

- ASTM E330-02
- ASTM E1886-02 and 13a
- ASTM E1996-02 and 17

Equivalency Evaluation per Product Approval Rule 61G20-3.015(4)(d):

Performance Testing

The following table shows the performance standards used in testing and those in the current edition of the FBC.

Standard Used in Testing		Current Edition of the Florida Building Code including the 8th Edition (2023) Florida Building Code		Comments
Description	Revision Level	Building Volume (FBC)	Residential Volume (FRC)	
ASTM E330	02	14	14	See Evaluation Below
ASTM E1886	02	13a	13a	
ASTM E1996	02	14a	14a	
ASTM E1886	13a	13a	13a	Meets 8 th Ed. (2023) FBC
ASTM E1996	17	17	17	

AAMA and/or ASTM's Listed Above: Based on review of performance standards used in testing and comparing them to the current revision levels in the 8th Edition (2023) Florida Building Code, it has been concluded that no material or substantive revisions or changes to these referenced standards have occurred (where applicable) that affect the results of design, testing or engineering of the approved product(s).



Equivalency Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2118-EER, Rev. 3 | Project No. 423-0305 | 9/25/23 | Page 2 of 2

Certificate of Independence per Product Approval Rule 61G20-3.009

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.

Evaluated By:
Robert J. Amoruso, P.E.
FL P.E. License Number 49752

