

L. Roberto Lomas P.E.

208 7th Avenue
Indialantic, FL 32903
434-688-0609
rllomas@lrlomaspe.com

FL 17047 ASTM EQ

August 17, 2023

To whom it may concern

Manufacturer: LAS Enterprises
2413 L & A Road
Metairie, LA 70001

Product Approval:

17047.1 Bahama shutter – Single panel
17047.2 Bahama shutter – Single mulled
17047.3 Bahama shutter – Twin mulled

Letter of Equivalency of Standards


This is to verify that the products mentioned above were tested according to ASTM E1886-05, ASTM E1996-09 and ASTM E330-02. I have reviewed these standards against the currently accepted standard ASTM E1886-19, ASTM E1996-20 and ASTM E330-14. Based on my reviewing I found that the testing requirements in ASTM E1886-05, ASTM E1996-09 and ASTM E330-02 are equivalent to the currently accepted standards.

Therefore, these products meet the testing requirements for ASTM E1886-19, ASTM E1996-20 and ASTM E330-14.

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

Sincerely



Luis R. Lomas P.E.
Florida No. 62514