

L. Roberto Lomas P.E.

400 S Palm Ave
Indialantic, FL 32903
434-688-0609
rlomas@lrlomaspe.com

FL 17159 ASTM EQ, Rev A

July 10, 2023

Manufacturer: Wojan Window and Door Corp.
217 Stover Road
Charlevoix, MI 49720

Product Approval:
17159.3 M950 Aluminum Single Hung Window


To whom it may concern

This is to verify that the products mentioned above were tested according to ASTM E1886-05 and ASTM E1996-05. I have reviewed the standards used for testing against the currently accepted standards ASTM E1886-19 and ASTM E1996-20. Based on my reviewing of these standards I found that the testing requirements in ASTM E1886-05 and ASTM E1996-05 are equivalent to the currently accepted standards.

Therefore, the products listed above meet the testing requirements for ASTM E1886-19 and ASTM E1996-20.

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas
FL No.: 62514
7/10/2023