

August 6, 2020

Equivalence of Product Standards

Product Description:

Series 8900 PVC Sliding Glass Doors WZ3, as detailed in Installation Instructions and Evaluation Reports CWS-928C and CWS-1042B

Manufacturer:

Custom Window Systems, Inc. 1900 SW 44th Ave, Ocala, FL 34474

Equivalent Standards:

ASTM E 1886-05 equivalent to ASTM E 1886-13a and
ASTM E 1996-05 or 09 equivalent to ASTM E 1996-17

Assessment:

The product indicated above has been tested to Wind Zone 3 criteria of ASTM E 1886-05 and ASTM E 1996-05/09. I have determined that for the indicated product as defined in the indicated Installation Instructions and Evaluation Reports, that this product testing is equivalent to that performed for Wind Zone 3 criteria of ASTM E 1886-13a and ASTM E 1996-17 as referenced in the 7th Edition (2020) Florida Building Code.



8/6/2020

Lucas A. Turner, P.E.

FL P.E. 58201