

L. Roberto Lomas P.E.

208 7th Ave
Indialantic, FL 32903
434-688-0609
rllomas@lrlomaspe.com

FL 17379 ASTM EQ

November 8, 2023

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Ft. Myers, FL 33912

Product Approval:

17379.1 5000 Series Aluminum Impact Double Outswing French Door
17379.2 5000 Series Aluminum Impact Single OS French Door W/Sidelites and Transom
17379.3 5000 Series Aluminum Impact Single Outswing French Door


To whom it may concern

This is to verify that the products mentioned above were tested according to ASTM E1886-05 and ASTM E1996-09. I have reviewed the standards used for testing against the currently accepted standards ASTM E1886-19 and ASTM E1996-20. Based on my reviewing of these standards I found that the testing requirements in ASTM E1886-05 and ASTM E1996-09 are equivalent to the currently accepted standards.

Therefore, the products listed above meet the testing requirements for ASTM E1886-19 and ASTM E1996-20.

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas
FL No.: 62514
11/8/2023