

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave  
Indialantic, FL 32903  
434-688-0609  
rllomas@lrlomaspe.com

*FL 18584 ASTM EQ Rev A*

August 18, 2023

**Manufacturer:** Nan Ya Plastics Corporation USA  
8989 North Loop East  
Houston, TX 77029

**Product Approval:**


18584.3 Series O/XO Gliding patio door fiberglass SGD W/Field mullion  
18584.4 Series O/XO Gliding patio door fiberglass SGD W/Field mullion

**To whom it may concern**

This is to verify that the products mentioned above were tested according to ASTM E1886-05 and ASTM E1996-09. I have reviewed the standards used for testing against the currently accepted standards ASTM E1886-19 and ASTM E1996-20. Based on my reviewing of these standards I found that the testing requirements in ASTM E1886-05, and ASTM E1996-09 are equivalent to the currently accepted standards. Therefore, the products listed above meet the testing requirements for ASTM E1886-19 and ASTM E1996-20.

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas  
FL No.: 62514  
8/18/2023