



October 18, 2023

Product Approval Administrator
DBPR Codes and Standards
2601 Blair Stone Road
Tallahassee, FL 32399

Regarding: Trane Technologies (See Applicable Sub-Products Below):

- American Standard Condenser (Ground Mounted) – FL #19588.1 – EX # 23-68282
- American Standard Condenser (Roof Mounted) – FL #19588.2 – EX # 23-68286
- Trane Condenser (Ground Mounted) - FL #19588.3 – EX # 23-68290
- Trane Condenser (Roof Mounted) - FL #19588.4 – EX # 23-68294

To Whom It May Concern:

This office has reviewed test report(s) showing structural performance of the above-noted product(s). These test report(s) pertain to testing performed in accordance with the referenced standard(s) in the table shown below. The noted standard(s) are not adopted in the Florida Building Code Eighth Edition (2023); however, for the purpose of determining the performance of the product, the standard(s) are equivalent to the corresponding standard(s), which are adopted in the above-referenced building code.

Note: "EX #" where used above is an abbreviation for "Engineering Express (EX) Project Number".

Code Title	Tests Performed according to:	Current Equivalent Standard
Test Method for Structural Performance of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference	ASTM E330-05	ASTM E330/E330M-14

Respectfully,

Frank Bennardo, P.E.
ENGINEERING EXPRESS®
#PE0046549 | Cert. Auth. 9885