

August 10, 2020

## Equivalence of Product Standards

### Product Description:

Series 8800 PVC Sliding Glass Doors, LM Impact, as detailed in Installation Instructions and Evaluation Reports CWS-1150B, CWS-1151B, and CWS-1152B

### Manufacturer:

Custom Window Systems, Inc. 1900 SW 44<sup>th</sup> Ave, Ocala, FL 34474

### Equivalent Standards:

ASTM E 1886-05 equivalent to ASTM E 1886-13a and  
ASTM E 1996-09 equivalent to ASTM E 1996-17

### Assessment:

The products indicated above have been tested to ASTM E 1886-05 and ASTM E 1996-09. I have determined that for the indicated products as defined in the indicated Installation Instructions and Evaluation Reports, that this product testing is equivalent to that performed for ASTM E 1886-13a and ASTM E 1996-17, as referenced in the 7<sup>th</sup> Edition (2020) Florida Building Code.



8/10/2020  
Lucas A. Turner, P.E.  
FL P.E. 58201