

December 6, 2021

Equivalence of Product Standards

Product Description:

M700 OS-C Outswing Impact Terrace Door

Manufacturer:

Quaker Commercial Windows and Doors, Freeburg, MO

Equivalent Standards:

ASTM E 1886-17 and ASTM E 1886-13a

Assessment:

The product indicated above has been tested to ASTM E 1886-17. The applicable version of this standard as listed in the 7th Edition (2020) Florida Building Code is ASTM E 1886-13a. I have determined that for the product indicated above, ASTM E 1886-17 and ASTM E 1886-13a are equivalent.



12/6/2021
Lucas A. Turner, P.E.
FL P.E. 58201