

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave  
Indialantic, FL 32903  
434-688-0609  
rllomas@lrlomaspe.com

*FL29714 EQ Rev A*

August 9, 2023

**To whom it may concern**

**Manufacturer:** Nan Ya Plastics Corporation USA  
8989 North Loop East  
Houston, TX 77029

**Product Approval:** 29714.1 SLPS Patio door lite 8'0 Outswing, Impact

Letter of Equivalency of Standards


This is to verify that the products mentioned above were tested according to ASTM E1886-05 and ASTM E1996-09. I have reviewed these standards against the currently accepted standard ASTM E1886-19 and ASTM E1996-20. Based on my reviewing I found that the testing requirements in ASTM E1886-05 and ASTM E1996-09 are equivalent to the currently accepted standards.

Therefore, these products meet the testing requirements for ASTM E1886-19 and ASTM E1996-20.

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

Sincerely



Luis R. Lomas P.E.  
Florida No. 62514