

July 27, 2023

Equivalence of Product Standards

Product Description:

V200 Single Hung Window, Single or Twin, as indicated in Florida Product Approval FL40320

Manufacturer:

Quaker Commercial Windows and Doors, Freeburg, MO

Equivalent Standards:

AAMA/WDMA/CSA 101/I.S.2/A440-05 and AAMA/WDMA/CSA 101/I.S.2/A440-17

Assessment:

The product indicated in the above-listed Florida Product Approval (FPA) has been tested and certified in accordance with AAMA/WDMA/CSA 101/I.S.2/A440-05. I have determined that for the indicated product as defined in the Certification, Installation Instructions, and Evaluation Report in the above-listed FPA, the pertinent air/water/structural testing performed as indicated above is equivalent to the testing performed for AAMA/WDMA/CSA 101/I.S.2/A440-17, as referenced in the 8th Edition (2023) Florida Building Code.



7/27/2023
Lucas A. Turner, P.E.
FL P.E. 58201