

April 28, 2022

Equivalence of Product Standards

Product Description:

Edgewater EH Doors, Single or Pair, Large Missile Impact

Florida Product Approval Number:

2020 FPA FL41446 line 1

Manufacturer:

Edgewater Door, Neenah, WI

Equivalent Standards:

ASTM E1886-19 and ASTM E1886-12
ASTM E1996-20 and ASTM E1996-17
ASTM E283/E283M-19 and ASTM E283-12
ASTM E330/E330M-21 and ASTM E330/E330M-14
ASTM E331-16 and ASTM E330-09

Assessment:

The products indicated above have been tested to ASTM E1886-19, ASTM E1996-20, ASTM E283/E283M-19, ASTM E330/E330M-21, and ASTM E331-16. Applicable versions of these standards as listed in the 7th Edition (2020) Florida Building Code are ASTM E1886-12, ASTM E1996-17, ASTM E283-12, ASTM E330/E330M-14, and ASTM E331-09, respectively. I have determined that for the indicated products in the Florida Product Approval number listed above, that the tested standards are equivalent to those required in the 7th Edition (2020) Florida Building Code.

4/28/2022

Lucas A. Turner, P.E.

FL P.E. 58201

