

L. Roberto Lomas P.E.

400 S. Palm Ave.
Indialantic, FL 32903
434-688-0609
rllomas@lrlomaspe.com

515027 EQ

May 25, 2022

Manufacturer: Stergis Windows & Doors
79 Walton St.
Attleboro, MA 02703


Product Line: Windgate/Belmont/Hawthorne Fixed Window, 72" x 96" Non-Impact

To whom it may concern

This is to verify that the products mentioned above were tested according to AAMA/WDMA/CSA 101/I.S.2/A440-05. I have reviewed the standards used for testing against the currently accepted standards AAMA/WDMA/CSA 101/I.S.2/A440-11. Based on my reviewing of these standards I found that the testing requirements in AAMA/WDMA/CSA 101/I.S.2/A440-05 are equivalent to the currently accepted standards. Therefore, the products listed above meet the testing requirements for AAMA/WDMA/CSA 101/I.S.2/A440-11.

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which the reports are being issued.

Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas
FL No.: 62514
5/25/2022