

August 6, 2020

## Equivalence of Product Standards

### Product Description:

Series 8400 PVC Casement Windows Non-Impact, as detailed in Installation Instructions and Evaluation Reports CWS-160F and CWS-508D

### Manufacturer:

Custom Window Systems, Inc. 1900 SW 44<sup>th</sup> Ave, Ocala, FL 34474

### Equivalent Standards:

AAMA/WDMA/CSA-101/IS2/A440-05 equivalent to AAMA/WDMA/CSA-101/IS2/A440-08

### Assessment:

The products indicated above have been tested in some configurations to AAMA/WDMA/CSA-101/IS2/A440-05. I have determined that for the indicated products as defined in the indicated Installation Instructions and Evaluation Reports, that this product testing is equivalent to that performed for AAMA/WDMA/CSA-101/IS2/A440-08 as referenced in the 7<sup>th</sup> Edition (2020) Florida Building Code.



8/6/2020

Lucas A. Turner, P.E.  
FL P.E. 58201