

April 26, 2023

Equivalence of Product Standards

Product Descriptions:

FL6393.5 TCC 022 + 5000 (426-H-708.04) Polycarb Dome
FL6393.7 TCR/TCC 014 + 1000 (426-H-706.08) Polycarb Dome
FL6393.9 TGC 022 + 5000 (426-H-708.05) Polycarb Dome
FL6393.11 TGF 014 + 1000 (426-H-705.05) Polycarb Dome
FL6393.13 TGF 022 + 1000 (426-H-705.05) Polycarb Dome
FL6393.15 TGR/TGC 010 or 014 + 1000 (426-H-705.06) Polycarb Dome
FL6393.17 TMF/TMR/THR 010 or 014 + 1000 (426-H-705.04) Polycarb Dome

Manufacturer:

Velux America, LLC, 85 Spencer Dr., Unit A, Wells, ME, 04090

Equivalent Standards:

ASTM E 1886-19 and ASTM E 1886-12
ASTM E 1996-20 and ASTM E 1996-12a

Assessment:

The products indicated in the above-listed Florida Product Approval (FPA) line items have been tested and certified in accordance with ASTM E 1886-19 and ASTM E 1996-20. I have determined that for the indicated products as defined in the Certifications and Installation Instructions in the above-listed FPA line items, the pertinent impact/cyclic testing performed as indicated above is equivalent to the testing performed for ASTM E 1886-12 and ASTM E 1996-12a, as referenced in the 7th Edition (2020) Florida Building Code.



4/26/2023
Lucas A. Turner, P.E.
FL P.E. 58201