

W. W. Schaefer Engineering & Consulting, P.A.

26376 Nadir Road; Unit 309

Punta Gorda, FL 33983

Phone: 561-744-3424

June 14, 2023

Re: Equivalency statement for ASTM E330, ASTM E1886 & ASTM E1996 testing of the following Kawneer Company products:

- 350 IR 9 ft. Tall LMI Out-Swing Doors
- 350/500 IR 8 ft. Tall LMI Out-swing Doors (Dry & Wet Glazed)

While applicable test reports state testing to ASTM E330-02, ASTM E1986-05 & ASTM E1996-05, upon review of that testing, we find that the testing performed on the applicable products referenced here-in also meets the requirements of the more current standards ASTM E330-14, ASTM E1986-13a & ASTM E1996-17 referenced in the 2023 FBC. Therefore, equivalency of standards has been met & reference to ASTM E330-14, ASTM E1986-13 & ASTM E1996-17 is acceptable.

Sincerely,

Warren W. Schaefer, P.E.
Florida P.E. #44135