L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 511659D

Manufacturer: Nan Ya Plastics Corp. USA

8989 North Loop East Houston, TX 77029

Product Line: Gliding Two Panel Patio Door, Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

- Approval document: drawing number 08-01099, Revision D, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No. FTL 6550 signed by Manny Sanchez.

Fenestration Testing Laboratory Inc. Medley, FL

AAMA/WDMA/CSA 101/I.S.Z/A440

Design pressure: ±50.0psf Water penetration resistance 7.5psf

3. Anchor calculations, report number 511659-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

Design pressure: ±50.0psf

Unit size: 71 3/8" x 79 1/2"

Approved configurations: XO and OX

- Units must be glazed per ASTM E1300-04/09, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-01099, Revision D.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

