

*L. Roberto Lomas P.E.*

1432 Woodford Rd.  
Lewisville, NC 27023  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 512959C

**Manufacturer:** Nan Ya Plastics Corp. USA  
8989 North Loop East  
Houston, TX 77029

**Product Line:** MasterPiece Series Gliding Patio Door, Nan Ya 6068 DP45, Non-Impact

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02239, Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: NCTL 210-3878-1 signed and sealed by Robert H Zeiders P.E.  
National Certified Testing Laboratories, York, PA  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure: ±45.0psf  
Water penetration resistance 6.75psf
3. Anchor calculations, report number 512959-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: ±45.0psf
- Unit size: 71 1/4" x 79 1/2"
- Units must be glazed per ASTM E 1300-04/09, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Co-Extruded PVC Foam or composite.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02239, Revision B.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

