

## Evaluation Report “Cee-Lock Panel” With Continous Cee-Rib Clip Metal Roof Assembly

**Manufacturer:**  
**Berridge Manufacturing Company**  
1720 Maury Road  
Houston, TX 77026  
(800) 231-8127

*for*

**Florida Product Approval**  
**# FL 11269.2 R8**  
**Florida Building Code 8th Edition (2023)**

**Method:** 1 - D  
**Category:** Roofing  
**Sub - Category:** Metal Roofing

**Product:** “Cee-Lock” Roof Panel  
**Material:** Steel  
**Panel Thickness:** 24 gauge or 22 gauge  
**Panel Width:** 11-3/4” or 16-1/2”  
**Support:** Steel Deck


This item has been digitally signed and sealed by James L. Buckner, P.E., on this date below. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.

### Prepared by:

James L. Buckner, P.E., S.E.C.B.  
Florida Professional Engineer # 31242  
Florida Evaluation ANE ID: 1916  
Project Manager: Diana Galloway  
Report No. 23-542-CL-SS-ER  
(Replaces 20-227-CL-S4,2S-ER, fka FL11269.2 R7)  
Date: 09/26/2023

### Contents:

Evaluation Report                      Pages 1 – 9



James L. Buckner, P.E.  
FL31242

Date: 2023.09.26 15:25:27  
1-04'00

<b>Manufacturer:</b>	<b>Berridge Manufacturing Company</b> 1720 Maury Road Houston, TX 77026 (800) 231-8127 <a href="http://www.berridge.com">www.berridge.com</a>
<b>Product Name:</b>	<b>“Cee-Lock”</b>
<b>Product Category:</b>	Roofing
<b>Product Sub-Category</b>	Metal Roofing
<b>Compliance Method:</b>	State Product Approval Rule 61G20-3.005 (1) (d)
<b>Product/System Description:</b>	“Cee-Lock” Snap-Lock Roof Panel
<b>Product Assembly as Evaluated:</b>	Refer to Page 4 of this report for product assembly components/materials & standards: <ol style="list-style-type: none"><li>1. Roof Panel</li><li>2. Panel Clip</li><li>3. Fasteners</li><li>4. Underlayment</li><li>5. Insulation</li></ol>
<b>Support:</b>	<b>Type:</b> Steel Deck (Design of support and its attachment to support framing is outside the scope of this evaluation.)  <b>Description:</b> <ul style="list-style-type: none"><li>• 24 gauge (min.) or 22 gauge per Table A</li><li>• Yield Strength: 40 ksi minimum</li></ul>
<b>Slope:</b>	Minimum slope shall be in compliance with FBC Chapter 15 Section 1507.4.2, applicable code sections and in accordance with manufacturer’s recommendations.
<b>Performance:</b>	Wind Uplift Resistance: <ul style="list-style-type: none"><li>• Design Uplift Pressure: <b>Refer to Table A</b> (Refer to “Table A” attachment details herein)</li></ul>

- Performance Standards:** The product described herein has demonstrated compliance with:
- UL580-06 – *Test for Uplift Resistance of Roof Assemblies*
  - UL 1897-15 – *Uplift test for roof covering systems*
  - TAS 125-03 – *Standard Requirements for Metal Roofing Systems*
- Standards Equivalency:** The UL 580-94 & UL 1897-98 standard version used to test the evaluated product assembly is equivalent with the prescribed standards in UL 580-06 & UL 1897-15 adopted by the Florida Building Code 8th Edition (2023).
- Code Compliance:** The product described herein has demonstrated compliance with Florida Building Code 8th Edition (2023), Section 1504.3.2.
- Evaluation Report Scope:** This product evaluation is limited to compliance with the structural requirements of the Florida Building Code, as related to the scope section to Florida Product Approval Rule 61G20-3.001.
- Limitations and Conditions of Use:**
- Scope of “Limitations and Conditions of Use” for this evaluation:  
This evaluation report for “Optional Statewide Approval” contains technical documentation, specifications and installation method(s) which include “Limitations and Conditions of Use” throughout the report in accordance with Rule 61G20-3.005. Per Rule 61G20-3.004, the Florida Building Commission is the authority to approve products under “Optional Statewide Approval”.
  - Option for application outside “Limitations and Conditions of Use”  
Rule 61G20-3.005(1)(e) allows engineering analysis for “project specific approval by the local authorities having jurisdiction in accordance with the alternate methods and materials authorized in the Code”. Any modification of the product as evaluated in this report and approved by the Florida Building Commission is outside the scope of this evaluation and will be the responsibility of others.
  - This report is a building code product evaluation per FLPE rule (FAC) 61G15-36 to comply with Florida product approval rule (FAC) 61G20-3. This evaluation report is part of the Florida Building Commission approval for the listed code related criteria. This report by James Buckner, P.E. and CBUGK Engineering is not a design certification of code compliance construction submittal documentation, per FBC section 107, for any individual structure, site specific or permit design.
  - All metal components and fasteners shall be corrosion resistant in accordance with applicable sections of FBC, including but limited to Sections 1504.3.2, 1506.6 and 1507.4.4.
  - Design of support system is outside the scope of this report.
  - Fire Classification is outside the scope of Rule 61G20-3, and is therefore not included in this evaluation.
  - This evaluation report does not evaluate the use of this product for use in the High Velocity Hurricane Zone code section. (Dade & Broward Counties)
- Quality Assurance:** The manufacturer has demonstrated compliance of roof panel products in accordance with the Florida Building Code and Rule 61G20-3.0005 (3) for manufacturing under a quality assurance program audited by an approved quality assurance entity through **UL, LLC.** (FBC Organization #: QUA 9625).

**Components/Materials  
(by Manufacturer):**

**Roof Panel:**  
Material: Berridge "Cee-Lock"  
Steel  
Thickness: 24 gauge or 22 gauge  
Panel Width: 16.5" (max.) or 11-3/4" (max.) Coverage  
Rib Height: 1-1/2"  
Yield Strength: 40 ksi min.  
Steel Grade: 40  
Corrosion Resistance: In compliance with FBC Section 1507.4.3:

- ASTM A792 coated, or
- ASTM A653 G90 galvanized steel

**Roof Panel Clips:**

Berridge "Cee-Rib" Clip  
Type: One-Piece, fixed continuous clip  
Material: Steel  
Thickness: 24 gauge min. or 22 gauge min. (See Table A)  
Dimensions: 1-7/16"(tall) x 1-3/8"(wide) x continuous (w/panel length)  
Yield Strength: 40 ksi min.  
Corrosion Resistance: Per FBC Section 1506.7

**Vinyl Weatherseal:**

Product: Berridge "Weatherseal"  
Product Identification: Patent 4641475  
Location: Snap on seam

**Fastener:**

**FASTENER 1:**

Size : **PICK ONE OF THE FOLLOWING:**  
Low Profile Self-Drilling Screws  
#12 x 7" (or length to meet min. penetration)  
w/3" steel disk per sheet when used w/insulation  
Corrosion Resistance: Per FBC Section 1506.6 and 1507.4.4  
Standard: Per FBC Section 1506.6

**FASTENER 2:**

Size : Low Profile Self-Tapping Screw  
#14 – 13 x 7", 9" (or length to meet min. penetration)  
w/3" steel disk per sheet when used w/insulation  
Corrosion Resistance: Per FBC Section 1506.6 and 1507.4.4  
Standard: Per FBC Section 1506.6

**Components & Materials:  
(by Others)**

**Underlayment:**

Material and application shall be in compliance with FBC Section 1507.1.1 and in accordance with applicable code sections and manufacturer's recommendations.

**Insulation (Optional with 16-1/2" panels):**

Type: Rigid Insulation Board  
Thickness: 4"(max.) or 4"-6"(max.) per Table A  
Properties:  
Density: 2.25 pcf (lbs/ft<sup>3</sup>) min.  
Or Compressive Strength: 20 psi min.

**Insulation Notes:**

- Rigid Insulation shall meet minimum density OR compressive strength.
- Insulation shall comply with FBC Section 1508. When insulation is incorporated, fastener length shall conform to penetrate thru bottom of support a minimum of 3/4".

**Installation:**

**Installation Method:**

(Refer to "TABLE A" below and drawings at the end of this report.)

- Fastener Spacing Along Continuous Clip:  
**Refer to "TABLE A" Below** (along the length of the panel)
- # fasteners per attachment point: **1**
- Rib Interlock: Snap-Lock  
 (Panel ribs shall be fully engaged to form an integral snap-lock.)
- Assemblies with insulation include 3" steel disk per sheet.
- Minimum fastener penetration thru bottom of support, 3/4".  
 (through bottom flute of steel deck)
- For panel construction at the end of panels, refer to manufacturer's instructions and any site specific design.

<b>TABLE "A"</b>									
<b>ALLOWABLE LOADS</b>									
	Panel Thickness	Deck Thickness	Max. Panel Width	Insulation (w/3" disk)	Fastener	Clip Thickness	Clip Fastener Spacing	Vinyl Weather Seal?	<b>DESIGN PRESSURE (PSF)</b>
<b>1</b>	24 ga. (min.)	24 ga. (min.)	11-3/4"	4"-6"	#14	24 ga. (min.)	16"	No	<b>- 123.5</b>
<b>2</b>	24 ga. (min.)	24 ga. (min.)	11-3/4"	4"-6"	#14	24 ga. (min.)	8"	No	<b>- 197.65</b>
<b>3</b>	24 ga. (min.)	24 ga. (min.)	16-1/2"	4" (max.) Optional	#12 or #14	24 ga. (min.)	18"	No	<b>- 82.5</b>
<b>4</b>	24 ga. (min.)	22 ga. (min.)	16-1/2"	4"-6"	#12 or #14	24 ga. (min.)	16"	No	<b>- 131</b>
<b>5</b>	22 ga. (min.)	22 ga. (min.)	16-1/2"	4" (max.) Optional	#14	22 ga. (min.)	8"	No	<b>- 183.5</b>
<b>6</b>	24 ga. (min.)	22 ga. (min.)	16-1/2"	4"-6"	#14	22 ga. (min.)	6"	Yes	<b>- 168.5</b>
<ul style="list-style-type: none"> <li>• Allowable design pressure(s) for allowable stress design (ASD).</li> </ul>									


Install the "Cee-Lock" roof panel assembly in compliance with the installation method listed in this report and applicable code sections of FBC 8th Edition (2023). The installation method described herein is in accordance with the scope of this evaluation report. Refer to manufacturer's installation instructions as a supplemental guide for attachment.

**Referenced Data:**


1. Uplift Test (Per UL580-94 and UL 1897-98)  
By Force Engineering & Testing Inc., Inc.  
(FBC Organization #TST ID: 5328)
  - Report # 49-0030T-02, Report Date: 11/27/02
  - Report # 49-0091T-02, Report Date: 8/18/08  
(Revision of Report # 49-0030T-02)
2. TAS 125-03 Uplift Test  
By Force Engineering & Testing Inc. (FBC Organization ID# TST 5328)  
Report # 49-0160T-10A, Dated 7/29/09
3. TAS 125-03 Uplift Test  
Force Engineering & Testing Inc. (FBC Organization ID# TST 5328)  
Report # 49-0374T-08A & B, Dated 2/2/09
4. TAS 125-03 Uplift Test  
By Force Engineering & Testing Inc. (FBC Organization ID# TST 5328)  
Report # 49-0188T-13A-C, Dated 10/9/13
5. TAS 125-03 Uplift Test  
By Force Engineering & Testing Inc. (FBC Organization ID# TST 5328)  
Report # 49-0009T-18A, Dated 4/11/18 (#6)
6. Quality Assurance  
UL, LLC (FBC Organization #: QUA 9625)
7. Equivalency of Test Standard Certification  
By James L. Buckner, P.E. @ CBLUECK Engineering  
(FBC Organization # ANE 1916)
8. Certification of Independence  
By James L. Buckner, P.E. @ CBLUECK Engineering  
(FBC Organization # ANE 1916)

**Installation Method  
Berridge Manufacturing Company  
"Cee-Lock" Steel Roof Panel attached to Steel Deck**

Drawings




**Typical Panel Profile**




**Berridge "Cee-Clip" and Continuous "Cee-Rib"  
Panel Clip Profile Side View**

**Installation Method  
Berridge Manufacturing Company  
"Cee-Lock" Steel Roof Panel attached to Steel Deck**



**Typical Assembly Profile View  
(Typical Fastening Pattern Across Width)**




\*U.S.PATENT NO. 4641475

**Typical Clip Assembly with Berridge Vinyl Weatherseal  
(Refer to Table A)**



## Installation Method Berridge Manufacturing Company "Cee-Lock" Steel Roof Panel attached to Steel Deck



**Typical Roof Assembly  
Isometric View**

TABLE "A"									
ALLOWABLE LOADS									
	Panel Thickness	Deck Thickness	Max. Panel Width	Insulation (w/3" disk)	Fastener	Clip Thickness	Clip Fastener Spacing	Vinyl Weather Seal?	DESIGN PRESSURE (PSF)
1	24 ga. (min.)	24 ga. (min.)	11-3/4"	4"-6"	#14	24 ga. (min.)	16"	No	- 123.5
2	24 ga. (min.)	24 ga. (min.)	11-3/4"	4"-6"	#14	24 ga. (min.)	8"	No	- 197.65
3	24 ga. (min.)	24 ga. (min.)	16-1/2"	4" (max.) Optional	#12 or #14	24 ga. (min.)	18"	No	- 82.5
4	24 ga. (min.)	22 ga. (min.)	16-1/2"	4"-6"	#12 or #14	24 ga. (min.)	16"	No	- 131
5	22 ga. (min.)	22 ga. (min.)	16-1/2"	4" (max.) Optional	#14	22 ga. (min.)	8"	No	- 183.5
6	24 ga. (min.)	22 ga. (min.)	16-1/2"	4"-6"	#14	22 ga. (min.)	6"	Yes	- 168.5