L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688 -0609 rllomas@lrlomaspe.com

Report No.: 512798J

Manufacturer: Provia, LLC.

2150 State Route 39 Sugarcreek, OH 44681

Product Line: Steel/Fiberglass Inswing Opaque Single Door W/ Sidelites and Transom Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-02084 revision I, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test Report No.: NCTL 110-15660-1 revision 7 signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

ASTM E330

Design pressure: ±55.0psf

3. Test Report No.: NCTL 110-15650-4 revision 1 signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±55.0psf
Water penetration resistance 8.25psf

Test Report No.: NCTL 110-15651-4 revision 1 signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±55.0psf
Water penetration resistance 8.25psf

5. Test Report No.: NCTL 110-15652-3 signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±55.0psf
Water penetration resistance 8.25psf

6. Test Report No.: 3172703MID-011, signed by Kent Kelsey

Intertek Testing Services NA Inc., Middleton, WI

NFPA 252 & UL 10C

Steel skin door with polyurethane foam core complies with NFPA 252 and UL 10C Positive Pressure Fire Test of Door Assemblies for a 90 minute rating with hose stream.

7. Test reports: TEL01680148, TEL01680149 and TEL01680150 signed and sealed by

Lyndon F. Schmidt P.E.

Testing Evaluation Laboratories, Inc. Plant City, FL.

Fiberglass testing

ASTM D635 Rate of burning classification: CC1
ASTM D1929 Self ignition temperature: 778°F
ASTM D2843 Smoke density rating: 60.4

8. Report No.: L0676.01-501-47-R0 signed by Stephen D. Shank.

Intertek, Springdale, PA.

AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±50.13psf
Water penetration resistance 0.0psf


. Test report No.: M4271.01-501-47 signed by Stephen D. Shank

Intertek, Springdale, PA

ASTM E330

Design pressure: +40.10/-45.11psf (Single point lock)

±50.13psf (Multi-point lock)



Luis R. Lomas, P.E. FL No.: 62514 08/30/2021

L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688 -0609 rllomas@lrlomaspe.com

Report No.: 512798J

- 10. Anchor calculations, report number 512798-1B, prepared, signed and sealed by Luis Roberto Lomas P.E
- 11. Mullion analysis, report number 512798-2 and -3, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 12. Comparative analysis, report number 511679-2, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 13. Evaluation and comparative analysis for alternate sills, report numbers 514581Å, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 14. Evaluation and comparative analysis, report number 514394A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 15. Evaluation for additional trims, report number 514783, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

Design pressure: ±55.0psf

Panel size: 35 3/4" x 94 15/16"


- Sidelite and transom must be glazed per ASTM E1300, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Door frame material: Wood G.46 minimum, or composite, or Framesaver, or Fusion Frame.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02084 revision I.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 08/30/2021