

Window Installation Calculations

K200 Direct Set Fixed Window

Report Q7587.01-122-34

Rendered to:

QUAKER WINDOWS AND DOORS
P.O. Box 128
Freeburg, Missouri 65035

Prepared by:


Tanya A. Dolby, P.E.
Adam Kunkel

Architectural Testing, Inc.
130 Derry Court
York, Pennsylvania 17406
(717) 764-7700
Florida COA: 29274

November 30, 2023

Tanya Dolby, P.E.
Manager, Engineering Services

Adam R. Kunkel
Project Engineer

	PROJECT: Window Installation Calculations – K200 Fixed	BY: TAD DATE: 11/30/23
	PROJECT NO.: Q7587.01-122-34	CKD: ARK SHEET: 2 OF 20

Scope

Architectural Testing, Inc., an Intertek company, was contracted by Quaker Windows & Doors to evaluate alternate installation methods for their K200 Direct Set Fixed windows. The evaluation is based on physical testing and product certifications.

Reference standards utilized in this project include:

Florida Building Code, Building, 8th Edition (2023). International Code Council, 2023.

ANSI/AWC NDS-2018 National Design Specification (NDS) for Wood Construction with 2018 Supplement. American Wood Council, 2018.

ADM1-2020 Aluminum Design Manual. The Aluminum Association, Inc., 2020.

AISI S100-16(2020) North American Specification for the Design of Cold-Formed Steel Structural Members, 2016 Edition (Reaffirmed 2020). American Iron and Steel Institute, 2020.

ICC-ES Report ESR-1976 ITW Buildex TEKS Self-Drilling Fasteners. ICC Evaluation Service. 01/2023.


NOA 21-0628.20 Hilti Kwik-Con + Concrete and Masonry Screw Anchor. Miami-Dade County Product Control Section. 12/12/2019.

The anchorage analyses presented herein do not address the water resistance, water penetration or air infiltration performance of the installation method or the installed product. In addition, the analyses rely on the assumption that the building substrate is capable of withstanding incurred loads.

Certification of Independence

In accordance with Rule 61G20-3 Florida Administrative Code, Architectural Testing, Inc. hereby certifies the following:

- Architectural Testing does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products tested or labeled by the agency.
- Architectural Testing is not owned, operated or controlled by any company manufacturing or distributing products it tests or labels.
- Tanya Dolby, P.E. and Adam Kunkel do not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the reports are being issued.
- Tanya Dolby, P.E. and Adam Kunkel do not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

	PROJECT: Window Installation Calculations – K200 Fixed	BY: TAD DATE: 11/30/23
	PROJECT NO.: Q7587.01-122-34	CKD: ARK SHEET: 3 OF 20

Analyses

Summary of Test Results

The following table summarizes the various K200 Direct Set Fixed Window products and their corresponding performance levels which have been established by testing or product certification.

Table 1 Summary of Test Results

Series/Model	Test Report Number	Product Certification	Size (W x H)	Performance
K200 Direct Set Fixed Window	82361.01-801-47	NI009663-R5 Expiration 4-30-26	64" x 71"	+/- 50 psf

Testing documented in Table 1 was conducted by the Architectural Testing laboratory in Plano, Texas (Florida Department of Business & Professional Regulation Test Lab No. TST1910, IAS Accredited Laboratory TL-331).

As-Tested Installation Analysis

For air/water/structural testing, the test specimen was secured to a 2x Spruce-Pine-Fir buck with #10 x 1-1/2" wood screws through the nail fin. The as-tested installation method is evaluated on page 6 and the established design capacity summarized in Table 2.

Table 2 As-tested Anchorage Design Capacities.

Test	Connection	Capacity
Air/Water/Structural Test	#10 x 1-1/2" Wood Screw Through Nail Fin Placed 6" from each corner and 10" on center	82 lb

The capacities presented in Table 2 will be used to prove acceptable alternate anchors and substrates for the windows.

Alternate Anchorages

Calculations on page 7 determine the design capacity of alternate fin installation anchorages for the window. The alternate anchorage capacities are summarized in Table 3.


Table 3 Alternate Anchorage Capacities for Fin Installation

Substrate	Anchor	Capacity	Comments
18 Gauge Steel Stud	#10-16 TEKS Screw	100 lb	<ol style="list-style-type: none"> 33 KSI yield strength stud. Full penetration +3 threads. Limited by pull-over capacity.

Page 8 through page 13 presents the calculation of alternate strap anchor installation anchorages for the window. The alternate anchorage capacities are summarized in Table 4.

Table 4 Alternate Anchorage Capacities for Strap Installation

Substrate	Anchor	Capacity	Comments
Wood SYP 2x	#10 x 1-1/2" Wood Screw	154 lb	<ol style="list-style-type: none"> 1-1/4" Minimum Penetration Limited by Mode III 1/4" Maximum Shim Space Southern Yellow Pine
18 Gauge Steel Stud	#10-16 TEKS Screw	139 lb	<ol style="list-style-type: none"> Minimum 18 gauge 33 KSI Steel Full penetration +3 threads Limited by bending 1/4" Maximum Shim Space
Concrete	3/16" Hilti Kwik Con +	215 lb	<ol style="list-style-type: none"> Minimum $f'_c = 3,000$ psi 1-3/4" Minimum Embedment 1-1/2" Min. Edge Distance Limited by shear capacity 1/4" Maximum Shim Space
CMU	3/16" Hilti Kwik Con +	150 lb	<ol style="list-style-type: none"> Minimum ASTM C90 CMU 1" Minimum Embedment 1-1/2" Min. Edge Distance Limited by shear capacity 1/4" Maximum Shim Space

	PROJECT: Window Installation Calculations – K200 Fixed	BY: TAD DATE: 11/30/23
	PROJECT NO.: Q7587.01-122-34	CKD: ARK SHEET: 5 OF 20

Anchorage Requirements

Although the capacities of the alternate anchorages exceed the capacity of the as-tested anchorage, it must be determined the anchorages are not overloaded for the approved window size and design pressures. Calculations presented in page 14 show required spacing for the evaluated anchorage conditions. Results are summarized in the following table.

Table 5 Anchorage Requirements

Substrate	Anchor	Spacing at Jambs	Spacing at Head/Sill
Wood S-P-F 2x	Fin Installation	11"	12"
	Strap Installation	21"	23"
18 Gauge Steel Stud	Fin Installation	14"	15"
	Strap Installation	19"	21"
Concrete	Strap Installation	29"	32"
CMU	Strap Installation	20"	23"

The spacings reported in Table 5 exceed the as-tested spacing reported in Table 2. Thus, the as-tested spacing shall govern.

Glass Analysis

Glass analysis report is provided on page 14. The Load Resistance capacity of the glass exceeds the as tested glass.

As-Tested Installation – Nail Fin to Wood

#10 x 1-1/2" Wood Screw

0.050" thick 6063-T6 Aluminum Nailing Fin

SYP 2x Wood Substrate Minimum (G=0.55)

Allowable Tension of #10 x 1-1/2" Wood Screw

$$W = 1.6(1.500''-0.050'')(163 \text{ lb/in}) \quad (\text{NDS, Table 11.2B})$$

$$W = 378 \text{ lb}$$

Pull-Over of #10 x 1-1/2" Wood Screw

$$P_{\text{nov}} = C_{\text{pov}} t_1 F_{\text{tu1}} (D_{\text{ws}} - D_{\text{h}}) / 3.0$$

$$P_{\text{nov}} = 1.0(0.050'')(30,000 \text{ psi})(0.365'' - 0.201'') / 3.0$$

$$P_{\text{nov}} = 82 \text{ lb}$$

Capacity of Connection is 82 lb

Alternate Installation – Nail Fin to Steel Stud

#10-16 TEKS Screw

0.050" thick 6063-T6 Aluminum Nailing Fin

Minimum 18 gauge 33 KSI Steel Stud

Allowable Tension of #10-16 TEKS Screw

$$P_{ss}/\Omega = 885 \text{ lb} \quad (\text{ESR-1976})$$

Pull-Over of #10-16 TEKS Screw

$$P_{nov} = C_{pov} t_1 F_{tu1} (D_{ws} - D_h) / 3.0$$

$$P_{nov} = 1.0(0.050")(30,000 \text{ psi})(0.365" - 0.201") / 3.0$$

$$P_{nov} = 100 \text{ lb}$$

Pull-Out of #10-16 TEKS Screw

$$P_{not} = 0.85 t_c d F_{u2} / 3.0$$

$$P_{not} = 0.85(0.0478")(0.190")(45,000 \text{ psi}) / 3.0$$

$$P_{not} = 116 \text{ lb}$$

Capacity of Connection is 100 lb

Alternate Installation – Strap Anchor to Wood

#10 x 1-1/2" Wood Screw

0.078" thick 6063-T6 Aluminum Strap Anchor

1/4" Maximum Shim Space

SYP 2x Wood Substrate Minimum (G=0.55)

Allowable Shear of #10 x 1-1/2" Wood Screw

$$Z' = 154 \text{ lb} \quad (\text{Limited by Mode III, See Following 2 Pages})$$

Bearing of #10 x 1-1/2" Wood Screw on Strap Anchor

$$V_a = 2DtF_u/n_u$$

$$V_a = 2(0.190")(0.078")(30,000 \text{ psi})/3.0$$

$$V_a = 296 \text{ lb}$$

Bending of #10 x 1-1/2" Wood Screw

$$L = 1/4" \text{ (maximum shim space)}$$

$$S = \pi d^3/32 = \pi(0.152")^3/32 = 0.000345 \text{ in}^3$$

$$F_b = (1.3)(0.6F_y) = (1.3)(0.6)(90,000 \text{ psi}) = 70,200 \text{ psi} \text{ (1.3 factor for weak axis bending)}$$

$$F_b = M/S = (VL/2)/S \text{ (L/2 for guided bending)}$$

$$V = 2SF_b/L = (2)(0.000345 \text{ in}^3)(70,200 \text{ psi})/0.25" = 194 \text{ lb}$$

Capacity of Connection is 154 lb

Alternate Installation – Strap Anchor to Wood (Continued)

Lateral Design Strength of Wood Connections

ANSI / AWC NDS-2018

Data

Fastener			
Fastener	=	#10 Wood Screw	
Shank Dia	=	0.190	in.
Root Dia.	=	0.152	in.
F _{yb}	=	80,000	psi
Fastener length	=	1.500	in.
Main Member			
Material	=	SPF	
G	=	0.55	
θ	=	90	<= (Angle of load to grain 0° ≤ θ ≤ 90°)
F _e	=	3,350	psi
Thickness	=	1.500	in.
Side Member			
Material	=	6063 T6 Aluminum	
G	=	N/A	
θ	=	0	<= (Angle of load to grain 0° ≤ θ ≤ 90°)
F _{es}	=	37,500	psi
Thickness	=	0.063	in.

Appendix J

NDS 2018

Calculations

Lateral Bearing Factors

D	=	0.152	in.
ℓ _m	=	1.057	in.
K _θ	=	1.25	
K _D	=	2.20	
R _e	=	0.089	
R _t	=	16.78	
k ₁	=	0.6084	
k ₂	=	0.6021	
k ₃	=	13.77	

Table 12.3.1B

Table 12.3.1B

Table 12.3.1A

Table 12.3.1A

Table 12.3.1A

Table 12.3.1A

Table 12.3.1A


Alternate Installation – Strap Anchor to Wood (Continued)

Yield Mode	R _d
I _m I _s	2.20
II	2.20
III _m III _s IV	2.20

Table 12.3.1B
 Table 12.3.1B
 Table 12.3.1B

Lateral Design Values, Z

Mode I _m	=	245	lbf		Eq 12.3-1
Mode I _s	=	163	lbf		Eq 12.3-2
Mode II	=	99	lbf		Eq 12.3-3
Mode III _m	=	125	lbf		Eq 12.3-4
Mode III _s	=	96	lbf	<===== Minimum Value	Eq 12.3-5
Mode IV	=	134	lbf		Eq 12.3-6
C _D	=	1.6			11.3.2
Wet Service Factor					
Fabrication/In-Service		Dry/Dry			
C _M	=	1.0			Table 11.3.3
In service temperature		T≤100°F			
C _t	=	1.0			Table 11.3.4
C _g	=	1.0			11.3.6
C _Δ	=	1.0			12.5.1
Is fastener installed in end grain?		No			
C _{eg}	=	1.00			12.5.2
Is fastener part of a diaphragm?		No			
C _{di}	=	1.0			12.5.3
Is fastener toe-nailed?		No			
C _{tn}	=	1.00			12.5.4
Z'	=	154	lbf		Table 12.3.1

	PROJECT: Window Installation Calculations – K200 Fixed	BY: TAD DATE: 11/30/23
	PROJECT NO.: Q7587.01-122-34	CKD: ARK SHEET: 11 OF 20

Alternate Installation – Strap Anchor to Steel Stud

#10-16 TEKS Screw

0.078" thick 6063-T6 Aluminum Strap Anchor

1/4" Maximum Shim Space

Minimum 18 gauge 33 KSI Steel Stud

Allowable Shear of #10-16 TEKS Screw

$$P_{ss}/\Omega = 573 \text{ lb (ESR-1976)}$$

Bearing of #10-16 TEKS Screw on Strap Anchor

$$V_a = 2DtF_u/n_u$$

$$V_a = 2(0.190")(0.078")(30,000 \text{ psi})/3.0$$

$$V_a = 296 \text{ lb}$$

Bearing of #10-16 TEKS Screw on Steel Stud

$$V_a = 2.7DtF_{tu}/3.0$$

$$V_a = 2.7(0.190")(0.0478")(45,000 \text{ psi})/3.0$$

$$V_a = 367 \text{ lb}$$

Tilting of #10-16 TEKS Screw in Steel Stud

$$V_a = 4.2(t_2^3 D)^{1/2} F_{tu2}/n_s$$

$$V_a = 4.2(0.0478^3 \times 0.190")^{1/2} (45,000 \text{ psi})/3.0$$

$$V_a = 287 \text{ lb}$$

Bending of #10-16 TEKS Screw

$$L = 1/4" \text{ (Maximum Shim Space)}$$


$$S = \pi d^3/32 = \pi(0.135")^3/32 = 0.000242 \text{ in}^3$$

$$F_b = (1.3)(0.6F_y) = (1.3)(0.6)(92,000 \text{ psi}) = 71,760 \text{ psi (1.3 factor for weak axis bending)}$$

$$F_b = M/S = (VL/2)/S \text{ (L/2 for guided bending)}$$

$$V = 2SF_b/L = (2)(0.000242 \text{ in}^3)(71,760 \text{ psi})/0.25" = 139 \text{ lb}$$

Capacity of Connection is 139 lb

	PROJECT: Window Installation Calculations – K200 Fixed	BY: TAD DATE: 11/30/23
	PROJECT NO.: Q7587.01-122-34	CKD: ARK SHEET: 12 OF 20

Alternate Installation – Strap Anchor to Concrete

3/16" Hilti Kwik-Con + Anchor

1-1/2" Minimum Edge Distance, 1-3/4" Minimum Embedment, 2" Minimum Spacing

1/4" Maximum Shim Space

0.078" thick 6063-T6 Aluminum Strap Anchor

Minimum $f'_c = 3,000$ psi Concrete

Allowable Shear of 3/16" Hilti Kwik-Con + Anchor

$$P_{ss}/\Omega = 215 \text{ lb} \quad (\text{NOA-No. 21-0628.20})$$

Bearing of 3/16" Hilti Kwik-Con + Anchor on Strap Anchor

$$V_a = 2DtF_u/n_u$$

$$V_a = 2(0.170")(0.078")(30,000 \text{ psi})/3.0$$

$$V_a = 265 \text{ lb}$$

Bending of 3/16" Hilti Kwik-Con +

$$L = 1/4" \text{ (Maximum Shim Space)}$$


$$S = \pi d^3/32 = \pi(0.170")^3/32 = 0.000482 \text{ in}^3$$

$$F_b = (1.3)(0.6F_y) = (1.3)(0.6)(137,000 \text{ psi}) = 106,860 \text{ psi} \text{ (1.3 factor for weak axis bending)}$$

$$F_b = M/S = (VL/2)/S \text{ (L/2 for guided bending)}$$

$$V = 2SF_b/L = (2)(0.000482 \text{ in}^3)(106,860 \text{ psi})/0.25" = 412 \text{ lb}$$

Capacity of Connection is 215 lb

	PROJECT: Window Installation Calculations – K200 Fixed	BY: TAD DATE: 11/30/23
	PROJECT NO.: Q7587.01-122-34	CKD: ARK SHEET: 13 OF 20

Alternate Installation – Strap Anchor to CMU

3/16" Hilti Kwik-Con + Anchor

1-1/2" Minimum Edge Distance, 1" Minimum Embedment, 3" Minimum Spacing

1/4" Maximum Shim Space

0.08" thick 6063-T6 Aluminum Strap Anchor

Minimum ASTM C90 CMU Block

Allowable Shear of 3/16" Hilti Kwik-Con + Anchor

$$P_{ss}/\Omega = 150 \text{ lb} \quad (\text{NOA-No. 21-0628.20})$$

Bearing of 3/16" Hilti Kwik-Con + Anchor on Strap Anchor

$$V_a = 2DtF_u/n_u$$

$$V_a = 2(0.170")(0.08")(30,000 \text{ psi})/3.0$$

$$V_a = 272 \text{ lb}$$

Bending of 3/16" Hilti Kwik-Con +

$$L = 1/4" \text{ (Maximum Shim Space)}$$

$$S = \pi d^3/32 = \pi(0.170")^3/32 = 0.000482 \text{ in}^3$$

$$F_b = (1.3)(0.6F_y) = (1.3)(0.6)(137,000 \text{ psi}) = 106,860 \text{ psi} \text{ (1.3 factor for weak axis bending)}$$

$$F_b = M/S = (VL/2)/S \text{ (L/2 for guided bending)}$$

$$V = 2SF_b/L = (2)(0.000482 \text{ in}^3)(106,860 \text{ psi})/0.25" = 412 \text{ lb}$$

Capacity of Connection is 150 lb

Analysis 1

Load Resistance Report

November 30, 2023

Details

Selected standard: ASTM E1300 Extended Basic

Glazing Construction (Double Glazed Insulating Unit)

Exterior Lite Properties (1/4 in. Monolithic)

Construction: 1/4 in. (AN)

Airspace Properties

Thickness: 0.480 in.

Interior Lite Properties (1/4 in. Monolithic)

Construction: 1/4 in. (AN)

Load Resistance

Short Duration (3 Sec)

Description	NEL	GTE	LSF	LR
Exterior Lite	40.9 psf	0.900	1/0.500	73.5 psf
Interior Lite	40.9 psf	0.900	1/0.500	73.5 psf

Comparisons

Scenario 1		
60.0 psf 3.00 sec <= 73.5 psf		OK
Approximate center of glass deflection		
Exterior Lite		0.63 in.
Interior Lite		0.63 in.

Notes

Load resistance values are computed in accordance with ASTM E1300-16 Section 6.2 and are based on non-factored load values calculated in a manner consistent with those presented in ASTM E1300-16.

Punched Opening Anchor Reactions

Window Design Pressure: 60.00

Substrate	Anchor	Capacity	Width, w (inch)	Height, h (inch)	JAMBS		HEAD/SILL	
					R (lb/in)	Calculated Anchor Spacing	R (lb/in)	Calculated Anchor Spacing
Wood	#10 Wood Screw at Nailing Fin	82 lb	64.00	71.00	7.32	11"	6.67	12"
	#10 Wood Screw at Strap	154 lb	64.00	71.00	7.32	21"	6.67	23"
Steel Stud	#10-16 TEKS at Nailing Fin	100 lb	64.00	71.00	7.32	14"	6.67	15"
	#10-16 TEKS at Strap	139 lb	64.00	71.00	7.32	19"	6.67	21"
Concrete CMU	3/16" Hilti Kwik-Con + at Strap	215 lb	64.00	71.00	7.32	29"	6.67	32"
	3/16" Hilti Kwik-Con + at Strap	150 lb	64.00	71.00	7.32	20"	6.67	23"

Appendix

HILTI KWIK-CON +

PRODUCT REVISED
 as complying with the Florida
 Building Code
 NOA-No. **21-0628.20**
 Expiration Date: **12/12/2024**
 By: *Manuel Perez*
 Miami-Dade Product Control

Hilti, Inc.
 7250 Dallas Parkway
 Plano TX 75024

DESCRIPTION


Carbon steel screw anchors have a minimum yield strength of 120 ksi and a minimum tensile strength of 150 ksi. The screw anchors have a zinc coating with a minimum thickness of 8 µm and are coated with an organic coating to resist corrosion. Three-sixteenths and 1/4-in. carbon steel screw anchors are available in 1-1/4, 1-3/4, 2-1/4, 2-3/4, 3-1/4 3-3/4 and 4 inch lengths.

Hilti Kwik-Con+ Fastening system for concrete and masonry elements
 Revision date: October 31, 2019
 Drawing: 1327-001
 Sheet no. 1 of 1


DESIGN LOADS:

Carbon steel screws					
Anchor size	Embedment depth	Concrete 300 psi		C90 Concrete block	
		Tension	Shear	Tension	Shear
3/16"	1"	112	215	116	150
3/16"	1-3/4"	217	215	-	-
1/4"	1"	198	379	122	251
1/4"	1-3/4"	393	379	-	-


Kwik-Con+ – Phillips flat head



Kwik-Con+ – Torx hex washer head



Kwik-Con+ – Torx flat head



For office use

PRODUCT APPROVED
 as complying with the Florida
 Building Code
 NOA-No. **19-1113.04**
 Approval Date **12/12/2019**
 By: *Manuel Perez*
 Miami-Dade Product Control

GENERAL NOTES

- Design loads for concrete are based on ultimate loads divided by 4. Design loads are for light-weight or normal-weight ASTM C90 block and are based on ultimate loads divided by 5.
- In order to achieve the design load, a minimum edge distance of 1-1/2" for 3/16" ø screw, and 2-1/2" for 1/4" ø screw shall be observed.
- Minimum spacing of anchor shall be 2" in concrete and 3" in concrete blocks in order to achieve the design loads.
- Anchor installation shall be made in accordance with Hilti's published installation instructions in the Product Technical Guide.
- Anchors are restricted from use in cracked concrete as defined in ACI 355.2.

Nominal diameter	Shank diameter (in.)	Thread major (in.)	Diameter root (in.)
3/16"	0.170	0.217	0.145
1/4"	0.224	0.283	0.190

Thomas Allan Kolden
 Professional Engineer
 Florida License No. 50899



TEKS Screw References

TABLE 5—FASTENER STRENGTH OF SCREWS^{1, 2, 3, 4, 5}

SCREW DESIGNATION	DIAMETER (in.)	ALLOWABLE FASTENER STRENGTH		NOMINAL FASTENER STRENGTH	
		Tensile, P_{ts}/Ω (lbf)	Shear, P_{ss}/Ω (lbf)	Tensile, P_{ts} (lbf)	Shear, P_{ss} (lbf)
10-16	0.190	885	573	2654	1718
12-14	0.216	1184	724	3551	2171
12-24	0.216	1583	885	4750	2654
1/4-14	0.250	1605	990	4816	2970
1/4-28	0.250	1922	1308	5767	3925

For S1: 1 inch = 25.4 mm, 1 lbf = 4.45 N.

¹For tension connections, the least of the allowable pull-out, pullover, and fastener tension strength found in Tables 2, 3, and 5, respectively, must be used for design.

²For shear connection, the lower of the allowable shear (bearing) and the allowable fastener shear strength found in Table 4 and 5, respectively, must be used for design.

³See Section 4.1 for fastener spacing and end distance requirements.

⁴Nominal strengths are based on laboratory tests

⁵To calculate LRFD values, multiply nominal strength values by the LRFD Φ factor of 0.5.

TABLE 22.11 (Spaced Threads)


6063-T6												
Nominal Thread Diameter & Thread Per Inch	D Nominal Thread Diameter (Inch)	Aluminum Thickness (Inches)										
		0.038	0.060	0.072	0.080	0.094	0.125	0.156	0.188	0.250	0.312	0.375
Allowable Pullout (Pounds)												
#8-18	0.1640	53	83	100	132	155	235	350	468	669	835	1004
#10-16	0.1900	61	96	116	153	180	239	372	509	775	968	1163
#12-14	0.2160	--	110	132	174	204	271	374	530	833	1100	1322
1/4-14	0.2500	--	127	152	201	236	314	433	614	964	1273	1530
5/16-12	0.3125	--	--	--	--	--	--	--	809	1334	1860	2296
3/8-12	0.3750	--	--	--	--	--	--	--	971	1601	2232	2755
				6063-T6								
F_U (Tensile Ultimate Strength)				30000 psi		Shading indicates transition region.						
F_Y (Tensile Yield Strength)				25000 psi								

NOTE 32:

- Each table lists allowable pull-out (internal threads) values. $S_F = 3.0$ for $D \leq 0.25"$; $S_F = 2.5$ for $D \geq 0.3125"$. Fastener allowable strength (basic tension and external threads) needs to be checked separately.
- For pilot hole sizes refer to tables 21.1 to 21.7
- Fastener pullout not shown for aluminum thickness less than approximately 2 threads, unless tested at a lesser thickness.
- Multiple fastener connections and embrittlement need to be checked separately.

WOOD SCREWS

 Pan Head w/
Phillips Recess

TYPE-17 DEEP THREAD

PAN PHILLIPS RECESS DEEP THREAD WOOD SCREW WITH TYPE-17 POINT

Nominal Diameter & Threads per Inch	A		H		R		M	D		T		Torque Kg/cm (Steel screws)	Recess Size
	Head Diameter		Head Height		Recess Penetration Depth		Recess Diameter	Major Diameter		Threaded Length			
	Max	Min	Max	Min	Max	Min	Ref	Max	Min	L ≤ 1"	L > 1"		
6-13	0.270	0.256	0.097	0.087	0.080	0.055	0.159	0.142	0.131	Full thread	2/3 thread	21	#2
7-12	0.296	0.281	0.106	0.096	0.089	0.064	0.170	0.158	0.147	Full thread	2/3 thread	28	#2
8-11	0.322	0.306	0.115	0.105	0.097	0.071	0.175	0.169	0.159	Full thread	2/3 thread	37	#2
10-9	0.373	0.357	0.133	0.122	0.113	0.089	0.192	0.194	0.185	Full thread	2/3 thread	55	#2
12-8	0.425	0.407	0.151	0.139	0.124	0.098	0.252	0.230	0.213	Full thread	2/3 thread	64	#3
Tolerance on Length	Up to 5/8"						± 0.03						
	Over 5/8 to 1.5"						± 0.05						
	Over 1.5 to 2.75"						± 0.06						
	Over 2.75"						± 0.09						

Description	An externally threaded fastener with a dome-shaped head, cross recess and a single lead thread. The shank has a reduced diameter and a chip cavity cut out where the final several threads end at the tip.	
Applications / Advantages	The deeper thread design offers greater resistance to pull-out forces. Popular in fastening cabinet hardware in locations that do not require the head to countersink. The chip cavity (or auger point) are designed to attach hinges to the edge of hardwood face frames.	Used in environments where corrosion resistance is necessary. The type-17 point enables the screw to more easily penetrate the material into which it's fastened. Can be used in particle board, wood and some plastics.
Material	C1018 - 1022 case-hardened steel	18-8 Stainless Steel
Surface Hardness	Vickers 450 HV minimum	
Case Depth	0.004" - 0.009"	
Torque	See values in above table	
Plating	See Appendix-A for plating information	Stainless deep thread screws are usually supplied without additional finish.

Tap & Clearance Drill Sizes				Tap Drill				Clearance Drill			
Screw Size	Major Diameter	Threads Per Inch	Minor Diameter	75% Thread for Aluminum, Brass, & Plastics		50% Thread for Steel, Stainless, & Iron		Close Fit		Free Fit	
				Drill Size	Dec. Eq.	Drill Size	Dec. Eq.	Drill Size	Dec. Eq.	Drill Size	Dec. Eq.
0	.0600	80	.0447	3/64	.0469	55	.0520	52	.0635	50	.0700
1	.0730	64	.0538	53	.0595	1/16	.0625	48	.0760	46	.0810
		72	.0560	53	.0595	52	.0635				
2	.0860	56	.0641	50	.0700	49	.0730	43	.0890	41	.0960
		64	.0668	50	.0700	48	.0760				
3	.0990	48	.0734	47	.0785	44	.0860	37	.1040	35	.1100
		56	.0771	45	.0820	43	.0890				
4	.1120	40	.0813	43	.0890	41	.0960	32	.1160	30	.1285
		48	.0864	42	.0935	40	.0980				
5	.125	40	.0943	38	.1015	7/64	.1094	30	.1285	29	.1360
		44	.0971	37	.1040	35	.1100				
6	.138	32	.0997	36	.1065	32	.1160	27	.1440	25	.1495
		40	.1073	33	.1130	31	.1200				
8	.1640	32	.1257	29	.1360	27	.1440	18	.1695	16	.1770
		36	.1299	29	.1360	26	.1470				
10	.1900	24	.1389	25	.1495	20	.1610	9	.1960	7	.2010
		32	.1517	21	.1590	18	.1695				
12	.2160	24	.1649	16	.1770	12	.1890	2	.2210	1	.2280
		28	.1722	14	.1820	10	.1935				
		32	.1777	13	.1850	9	.1960				
1/4	.2500	20	.1887	7	.2010	7/32	.2188	F	.2570	H	.2660
		28	.2062	3	.2130	1	.2280				
		32	.2117	7/32	.2188	1	.2280				
5/16	.3125	18	.2443	F	.2570	J	.2770	P	.3230	Q	.3320
		24	.2614	I	.2720	9/32	.2812				
		32	.2742	9/32	.2812	L	.2900				
3/8	.3750	16	.2983	5/16	.3125	Q	.3320	W	.3860	X	.3970
		24	.3239	Q	.3320	S	.3480				
		32	.3367	11/32	.3438	T	.3580				
7/16	.4375	14	.3499	U	.3680	25/64	.3906	29/64	.4531	15/32	.4687
		20	.3762	25/64	.3906	13/32	.4062				
		28	.3937	Y	.4040	Z	.4130				
1/2	.5000	13	.4056	27/64	.4219	29/64	.4531	33/64	.5156	17/32	.5312
		20	.4387	29/64	.4531	15/32	.4688				
		28	.4562	15/32	.4688	15/32	.4688				
9/16	.5625	12	.4603	31/64	.4844	33/64	.5156	37/64	.5781	19/32	.5938
		18	.4943	33/64	.5156	17/32	.5312				
		24	.5114	33/64	.5156	17/32	.5312				
5/8	.6250	11	.5135	17/32	.5312	9/16	.5625	41/64	.6406	21/32	.6562
		18	.5568	37/64	.5781	19/32	.5938				
		24	.5739	37/64	.5781	19/32	.5938				
11/16	.6875	24	.6364	41/64	.6406	21/32	.6562	45/64	.7031	23/32	.7188
3/4	.7500	10	.6273	21/32	.6562	11/16	.6875	49/64	.7656	25/32	.7812
		16	.6733	11/16	.6875	45/64	.7031				
		20	.6887	45/64	.7031	23/32	.7188				
13/16	.8125	20	.7512	49/64	.7656	25/32	.7812	53/64	.8281	27/32	.8438
7/8	.8750	9	.7387	49/64	.7656	51/64	.7969	57/64	.8906	29/32	.9062
		14	.7874	13/16	.8125	53/64	.8281				
		20	.8137	53/64	.8281	27/32	.8438				
15/16	.9375	20	.8762	57/64	.8906	29/32	.9062	61/64	.9531	31/32	.9688
1	1.000	8	.8466	7/8	.8750	59/64	.9219	1-1/64	1.0156	1-1/32	1.0313
		12	.8978	15/16	.9375	61/64	.9531				
		20	.9387	61/64	.9531	31/32	.9688				



PROJECT: Window Installation Calculations – K200 Fixed

BY: TAD DATE: 11/30/23

PROJECT NO.: Q7587.01-122-34

CKD: ARK SHEET: 20 OF 20

Revision Log

<u>Rev. #</u>	<u>Date</u>	<u>Page(s)</u>	<u>Revision(s)</u>
0	11/30/23	N/A	Original report issue