



Project No.: 27561.04-107-16
Project Name: Contours Steel Wood Edge
Inswing/Outswing Glazed XX
Revision 2 Date: 4/23/2024
Page 1 of 16

PRODUCT APPROVAL SUPPORTING CALCULATIONS

Series/Model: Contours Steel Wood Edge Inswing/Outswing Glazed XX

REPORT No.: 27561.04-107-16

RENDERED TO: Jeld-Wen Windows & Doors
3737 Lakeport Blvd
Klamath Falls, Oregon

PREPARED BY: Michael D. Stremmel, P.E.
Molimo, LLC
1410 Eden Road
York, Pennsylvania 17402

REVISION 2 DATE: 4/23/2024

This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal.

Printed copies of this document are not considered signed and sealed and the signature must be verified on electronic copies.

Michael D. Stremmel, P.E.
Senior Project Engineer
FL PE 65868
FL REG 37122

It is a violation to alter this document in any way unless acting under the direction of a licensed professional engineer.



Project No.: 27561.04-107-16
Project Name: Contours Steel Wood Edge
Inswing/Outswing Glazed XX
Revision 2 Date: 4/23/2024
Page 2 of 16

SCOPE:

Molimo, LLC was contracted by Jeld-Wen Windows & Doors to evaluate alternate installation methods for their Contours Steel Wood Edge Inswing/Outswing Glazed XX. The evaluation is based on physical testing and product certifications.

Reference standards utilized in this project include:

Florida Building Code. International Code Council.

ANSI/AWC National Design Specification (NDS) for Wood Construction. American Wood Council.

AISI S100 North American Specification for the Design of Cold-Formed Steel Structural Members. American Iron and Steel Institute.

ICC-ES Report ESR-1976 ITW Buildex TEKS Self-Drilling Fasteners. ICC Evaluation Service.

NOA 21-0201.06 *Tapcon Concrete and Masonry Anchors with Advanced Threadform Technology.* Miami-Dade County Product Control Section.

The anchorage analysis presented herein does not address the water resistance, water penetration, or air infiltration performance of the installation method or the installed product. In addition, the analyses rely on the assumption that the building substrate is capable of withstanding the incurred loads.



Project No.: 27561.04-107-16
Project Name: Contours Steel Wood Edge
Inswing/Outswing Glazed XX
Revision 2 Date: 4/23/2024
Page 3 of 16

Certification of Independence

In accordance with Rule 61G20-3 Florida Administrative Code, Molimo, LLC hereby certifies the following:

- Molimo, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products tested or labeled by the agency.
- Molimo LLC is not owned, operated or controlled by any company manufacturing or distributing products it tests or labels.
- Michael D. Stremmel, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the reports are being issued.
- Michael D. Stremmel, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

ANALYSES:

Summary of Test Results

Table 1 summarizes the various Contours Steel Wood Edge Inswing/Outswing Glazed XX products and their corresponding performance levels which have been established by testing or product certification.

Table 1: Summary of Test Results

Series/Model	Test Report Number	Size (W x H)	Performance
Jeld-Wen Wood-Edge Steel Double In-swing and Out-swing Entry Doors	National Certified Testing Laboratories Report No. NCTL-210-3195-1 (9/28/2005)	74" x 83" (Out-Swing)	+60 / -60 psf (Wind Zone 4)
Jeld-Wen Wood-Edge Steel Double In-swing and Out-swing Entry Doors	National Certified Testing Laboratories Report No. NCTL-210-3195-1 (9/28/2005)	74" x 83" (In-Swing)	+60 / -60 psf (Wind Zone 4)

Testing documented in Table 1 was conducted by National Certified Testing Laboratories of Orlando, Florida (Florida Department of Business & Professional Regulation Test Lab No. TST1589 – laboratory was approved at the time of testing). The testing documented above is certified by NAMI under certification number NI006255-R11 (Expires 9/30/2027).

ANALYSES:

Summary of Test Results

Table 2: Plastics Checklist of Test Results

Product	Test Report Number	Test Standard	Test Results
Dylite Expandable Polystyrene	Intertek Report No. 3113726SAT-001 Rev. 1 (3/13/2009)	ASTM E84	Flame Spread: 35 Smoke Developed: 450
White PVC 1476 5110	Intertek Report No. P6504.01-106-18-R0 (8/23/2023)	ASTM D638 (before and after G155)	+9.5%
		ASTM D1929	824°F (440°C)
		ASTM D2843	71.8
		ASTM D635	Class CC1
White PVC 1476 5290	Intertek Report No. P6504.01-106-18-R0 (8/23/2023)	ASTM D638 (before and after G155)	+9.5%
		ASTM D1929	806°F (430°C)
		ASTM D2843	72.6
		ASTM D635	Class CC1
SMC Skin	Element Report No. ESP010982P (2/26/2013)	ASTM D638 (before and after G155)	-2.2%
		ASTM D1929	770°F (410°C)
		ASTM D2843	62
		ASTM D635	Class CC2

Testing documented in Table 2 was conducted by Intertek of York, Pennsylvania (Florida Department of Business & Professional Regulation Test Lab No. TST1558) and Intertek of Elmendorf, Texas (Florida Department of Business & Professional Regulation Test Lab No. TST1585) and Element Materials Technology of St Paul, Minnesota.

The test results listed in Table 2 meet the requirements listed in Miami-Dade County Checklist #0445, *For the Approval of: Plastic and Foam Plastic.*



Project No.: 27561.04-107-16
Project Name: Contours Steel Wood Edge
Inswing/Outswing Glazed XX
Revision 2 Date: 4/23/2024
Page 6 of 16

As-Tested Installation Analysis

For air/water/structural testing, the test specimen was secured to a Douglas-Fir wood test buck with #8 wood screws (1-1/2" min. embedment) at the head, sill, and jambs. The as tested installation method is evaluated on Pages 7 and 8. These capacities will be used to prove acceptable anchors and substrates for the product.

Alternate Anchorages

Calculations on Pages 9 through 15 determine the design capacity of alternate installation anchorages for the product.

Anchorages Requirements

As-tested spacing must be maintained. It must be determined that the anchorages are not overloaded for the approved product size and design pressures. Calculations presented on Page 16 show the alternate anchorages are acceptable for the established product performance.

Anchorage requirements established by this report are accurately presented in Drawing D1000366.



Project No.: 27561.04-107-16
Project Name: Contours Steel Wood Edge
Inswing/Outswing Glazed XX
Revision 2 Date: 4/23/2024
Page 7 of 16

As-Tested Installation – Through Frame to Wood

Anchor: #8 x 2-1/2" Wood Screw
(1-1/2" min embedment})

Details: 0.719" thick wood frame (G = 0.42)
No shim space was utilized

Substrate: Douglas-Fir wood test buck (G = 0.46)

Wood Screw Capacity (Shear)

Z' = 111 lb

(See Following Page)

Design Capacity of the Connection = 111 lb

Lateral Design Strength of Wood Connections

Data

Fastener

Fastener	=	#8 Wood Screw
Shank Dia	=	0.164 in.
Root Dia.	=	0.131 in.
F_{yb}	=	90,000 psi
Fastener length	=	2.250 in.

Project:	Contours Steel Wood Edge Inswing Glazed XX
Comments:	As-tested Installation 1-1/2" min embedment

Main Member

Material	=	Douglas Fir (South)
G	=	0.46
θ	=	90
F_e	=	4,000 psi
Thickness	=	1.500 in.

Side Member

Material	=	SPF
G	=	0.42
θ	=	90
F_{es}	=	3,350 psi
Thickness	=	0.719 in.

Calculations

Lateral Bearing Factors

D	=	0.131 in.
ℓ_m	=	1.352 in.
K_θ	=	1.25
K_D	=	2.20
R_e	=	1.194
R_t	=	1.88

k_1	=	0.7342
k_2	=	1.2058
k_3	=	1.29
R_d	=	2.20 (Mode I _m , I _s)
R_d	=	2.20 (Mode II)
R_d	=	2.20 (Mode III _m , III _s , IV)

Lateral Design Values, Z

Mode I _m	=	322 lbf
Mode I _s	=	143 lbf
Mode II	=	105 lbf
Mode III _m	=	115 lbf
Mode III _s	=	69 lbf
Mode IV	=	82 lbf

<== Minimum Value

Adjustment Factors

C_D	=	1.6
Wet Service Factor		
Fabrication/In-Service		Dry/Dry
C_M	=	1.0
In service temperature		$T \leq 100^\circ\text{F}$
C_t	=	1.0
C_g	=	1.0

C_Δ	=	1.0
Is fastener installed in end grain?		No
C_{eg}	=	1.00
Is fastener part of a diaphragm?		No
C_{di}	=	1.0
Is fastener toe-nailed?		No
C_{tn}	=	1.00

Adjusted Design Value, Z

Z'	=	<u>111</u> lbf
----	---	----------------

Alternate Installation – Strap Anchor to Wood

Anchor: #8 x 1-1/2" Flat head screw securing the strap to the substrate
 1/4" max shim space

Details: 20 gauge (0.033" thick) 33 KSI steel strap anchor w/ two #8 screws securing the strap to the frame
 1-1/2" thick wood frame

Substrate: Spruce-Pine-Fir 2x Wood Substrate (G = 0.42 min.)

Wood Screw Capacity (Shear)

$$Z' = \underline{122 \text{ lb}}$$

(See Following Page)

Bending of #8 x 1-1/2" flat head screw

$$L = 1/4" \text{ (maximum shim space)}$$

$$S = \pi d^3 / 32 = \pi (0.131")^3 / 32 = 0.000221 \text{ in}^3$$

$$F_b = (1.3)(0.6 F_y) = (1.3)(0.6)(90,000 \text{ psi}) = 70,200 \text{ psi} \quad (1.3 \text{ for weak axis bending})$$

$$F_b = M / S = (V) (L/2) / S \quad (L/2 \text{ for guided bending})$$

$$V = 2 S F_b / L = (2)(0.000221 \text{ in}^3)(70,200 \text{ psi}) / 1/4"$$

$$V = \underline{124 \text{ lb}}$$

Bearing Capacity (of #8 screw on frame)

$$P_b = F_e D t / K_D = (3,350 \text{ psi})(0.164")(0.719") / (10(0.164) + 0.5) = \underline{184 \text{ lb}}$$

Bearing Capacity (of strap anchor)

$$P_b = 2.7 D t F_{tu} = 2.7(0.164")(0.033")(45,000 \text{ psi}) = 657 \text{ lb}$$

$$P_{\text{allow}} = 657 \text{ lb} / 3.0 = \underline{219 \text{ lb}}$$

Design Capacity of the Connection = 122 lb

Lateral Design Strength of Wood Connections

Data

Fastener

Fastener	=	#8 Wood Screw
Shank Dia	=	0.164 in.
Root Dia.	=	0.131 in.
F_{yb}	=	90,000 psi
Fastener length	=	1.500 in.

Project:	Contours Steel Wood Edge inswing Glazed XX
Comments:	Steel Strap Installation 1-1/2" min embedment

Main Member

Material	=	SPF
G	=	0.42
θ	=	90
F_e	=	3,350 psi
Thickness	=	1.500 in.

Side Member

Material	=	ASTM A 653, Grade 33 Steel
G	=	N/A
θ	=	90
F_{es}	=	61,850 psi
Thickness	=	0.033 in.

Calculations

Lateral Bearing Factors

D	=	0.131 in.
ℓ_m	=	1.303 in.
K_θ	=	1.25
K_D	=	2.20
R_e	=	0.054
R_t	=	39.48

k_1	=	0.8723
k_2	=	0.5195
k_3	=	23.87
R_d	=	2.20 (Mode I _m , I _s)
R_d	=	2.20 (Mode II)
R_d	=	2.20 (Mode III _m , III _s , IV)

Lateral Design Values, Z

Mode I _m	=	260 lbf
Mode I _s	=	122 lbf
Mode II	=	106 lbf
Mode III _m	=	122 lbf
Mode III _s	=	77 lbf
Mode IV	=	108 lbf

<== Minimum Value

Adjustment Factors

C_D	=	1.6
Wet Service Factor		
Fabrication/In-Service Dry/Dry		
C_M	=	1.0
In service temperature $T \leq 100^\circ\text{F}$		
C_t	=	1.0
C_g	=	1.0

C_Δ	=	1.0
Is fastener installed in end grain?		
		No
C_{eg}	=	1.00
Is fastener part of a diaphragm?		
		No
C_{di}	=	1.0
Is fastener toe-nailed?		
		No
C_{tn}	=	1.00

Adjusted Design Value, Z

Z'	=	<u>122</u> lbf
------	---	----------------

Alternate Installation – Through-Frame to Concrete

Anchor: 3/16" Tapcon Anchor
- 1-1/4" min embedment
- 2-1/2" min edge distance
- 4" min anchor spacing
- 1/4" max shim space

Details: Through the Wood Frame
- 1" thick

Substrate: 3,000 psi Concrete

Anchor Capacity (Shear of 3/16" Tapcon)

$$P_{ss} / \Omega = \underline{181 \text{ lb}} \quad (\text{NOA-No. 16-1222.06})$$

Bearing Capacity (of Wood frame)

$$P_b = F_e D t / K_D = (3,350 \text{ psi})(0.170")(1.00") / (10(0.170) + 0.5) = \underline{259 \text{ lb}}$$

Bending Capacity (of 3/16" Tapcon)

$$L = 1/4" \text{ (maximum shim space)}$$

$$S = \pi d^3 / 32 = \pi (0.170")^3 / 32 = 0.000482 \text{ in}^3$$

$$F_b = (1.3)(0.6 F_y) = (1.3)(0.6)(137,000 \text{ psi}) = 106,860 \text{ psi} \quad (1.3 \text{ for weak axis bending})$$

$$F_b = M / S = (V) (L/2) / S \quad (L/2 \text{ for guided bending})$$

$$V = 2 S F_b / L = (2)(0.000482 \text{ in}^3)(106,860 \text{ psi}) / 1/4"$$

$$V = \underline{412 \text{ lb}}$$

Design Capacity of the Connection = 181 lb

Qualifies 1/4" Tapcon if longer length anchor is required to achieve minimum embedment

Alternate Installation – Through-Frame to CMU Block

Anchor: 3/16" Tapcon Anchor
- 1-1/4" min embedment
- 2-1/2" min edge distance
- 4" min anchor spacing
- 1/4" max shim space

Details: Through the Wood Frame
- 1" thick

Substrate: CMU Block

Anchor Capacity (Shear of 3/16" Tapcon)

$$P_{ss} / \Omega = \underline{135 \text{ lb}} \quad (\text{NOA-No. 16-1222.06})$$

Bearing Capacity (of Wood frame)

$$P_b = F_e D t / K_D = (3,350 \text{ psi})(0.170")(1.00") / (10(0.170) + 0.5) = \underline{259 \text{ lb}}$$

Bending Capacity (of 3/16" Tapcon)

$$L = 1/4" \text{ (maximum shim space)}$$

$$S = \pi d^3 / 32 = \pi (0.170")^3 / 32 = 0.000482 \text{ in}^3$$

$$F_b = (1.3)(0.6 F_y) = (1.3)(0.6)(137,000 \text{ psi}) = 106,860 \text{ psi} \quad (1.3 \text{ for weak axis bending})$$

$$F_b = M / S = (V) (L/2) / S \quad (L/2 \text{ for guided bending})$$

$$V = 2 S F_b / L = (2)(0.000482 \text{ in}^3)(106,860 \text{ psi}) / 1/4"$$

$$V = \underline{412 \text{ lb}}$$

Design Capacity of the Connection = 135 lb

Qualifies 1/4" Tapcon if longer length anchor is required to achieve minimum embedment

Alternate Installation – Strap Anchor to Concrete

Anchor: 3/16" Tapcon Anchor
 - 1-1/4" min embedment
 - 2-1/2" min edge distance
 - 4" min anchor spacing
 - 1/4" max shim space

Details: 20 gauge (0.033" thick) 33 KSI steel strap anchor w/ two #8 screws securing the strap to the frame
 1.00" thick wood frame

Substrate: 3,000 psi Concrete

Anchor Capacity (Shear of 3/16" Tapcon)

$$P_{ss} / \Omega = \underline{181 \text{ lb}} \quad (\text{NOA-No. 16-1222.06})$$

Bearing Capacity (of 3/16" Tapcon on strap anchor)

$$P_b = 2.7 D t F_{tu} = 2.7(0.170")(0.033")(45,000 \text{ psi}) = 681 \text{ lb}$$

$$P_{\text{allow}} = 681 \text{ lb} / 3.0 = \underline{227 \text{ lb}}$$

Bearing Capacity (of #8 screw on frame)

$$P_b = F_e D t / K_D = (3,350 \text{ psi})(0.164")(1.00") / (10(0.164) + 0.5) = \underline{257 \text{ lb}}$$

Bearing Capacity (of #8 screw on strap anchor)

$$P_b = 2.7 D t F_{tu} = 2.7(0.164")(0.033")(45,000 \text{ psi}) = 657 \text{ lb}$$

$$P_{\text{allow}} = 657 \text{ lb} / 3.0 = \underline{219 \text{ lb}}$$

Bending Capacity (of 3/16" Tapcon)

$$L = 1/4" \text{ (maximum shim space)}$$

$$S = \pi d^3 / 32 = \pi (0.170")^3 / 32 = 0.000482 \text{ in}^3$$

$$F_b = (1.3)(0.6 F_y) = (1.3)(0.6)(137,000 \text{ psi}) = 106,860 \text{ psi} \quad (1.3 \text{ for weak axis bending})$$

$$F_b = M / S = (V) (L/2) / S \quad (L/2 \text{ for guided bending})$$

$$V = 2 S F_b / L = (2)(0.000482 \text{ in}^3)(106,860 \text{ psi}) / 1/4"$$

$$V = \underline{412 \text{ lb}}$$

Design Capacity of the Connection = 181 lb (one concrete anchor per strap)

Qualifies 1/4" Tapcon if longer length anchor is required to achieve minimum embedment

Alternate Installation – Strap Anchor to CMU Block

Anchor: 3/16" Tapcon Anchor
- 1-1/4" min embedment
- 2-1/2" min edge distance
- 4" min anchor spacing
- 1/4" max shim space

Details: 20 gauge (0.033" thick) 33 KSI steel strap anchor w/ two #8 screws securing the strap to the frame
1.00" thick wood frame

Substrate: CMU Block

Anchor Capacity (Shear of 3/16" Tapcon)

$$P_{ss} / \Omega = \underline{135 \text{ lb}} \quad (\text{NOA-No. 16-1222.06})$$

Bearing Capacity (of 3/16" Tapcon on strap anchor)

$$P_b = 2.7 D t F_{tu} = 2.7(0.170")(0.033")(45,000 \text{ psi}) = 681 \text{ lb}$$

$$P_{\text{allow}} = 681 \text{ lb} / 3.0 = \underline{227 \text{ lb}}$$

Bearing Capacity (of #8 screw on frame)

$$P_b = F_e D t / K_D = (3,350 \text{ psi})(0.164")(1.00") / (10(0.164) + 0.5) = \underline{257 \text{ lb}}$$

Bearing Capacity (of #8 screw on strap anchor)

$$P_b = 2.7 D t F_{tu} = 2.7(0.164")(0.033")(45,000 \text{ psi}) = 657 \text{ lb}$$

$$P_{\text{allow}} = 657 \text{ lb} / 3.0 = \underline{219 \text{ lb}}$$

Bending Capacity (of 3/16" Tapcon)

$$L = 1/4" \text{ (maximum shim space)}$$

$$S = \pi d^3 / 32 = \pi (0.170")^3 / 32 = 0.000482 \text{ in}^3$$

$$F_b = (1.3)(0.6 F_y) = (1.3)(0.6)(137,000 \text{ psi}) = 106,860 \text{ psi} \quad (1.3 \text{ for weak axis bending})$$

$$F_b = M / S = (V) (L/2) / S \quad (L/2 \text{ for guided bending})$$

$$V = 2 S F_b / L = (2)(0.000482 \text{ in}^3)(106,860 \text{ psi}) / 1/4"$$

$$V = \underline{412 \text{ lb}}$$

Design Capacity of the Connection = 135 lb (one concrete anchor per strap)

Qualifies 1/4" Tapcon if longer length anchor is required to achieve minimum embedment

Alternate Installation – Strap Anchor to Wood (Cap Installation)

Anchor: Two #8 x 1-1/2" Flat head screw securing the strap to the substrate

Details: 20 gauge (0.033" thick) 33 KSI steel strap anchor w/ two #8 screws securing the strap to the frame
1.00" thick wood frame
1/4" max shim space

Substrate: Spruce-Pine-Fir 2x Wood Substrate (G = 0.42 min.)

Wood Screw Capacity (Withdrawal)

$$W' = 1.6(82 \text{ lb/in})(1.5 \text{ in}) = \underline{197 \text{ lb}}$$

Pull-over Capacity (of #8 screw on strap)

$$P_{\text{nov}} = 1.5 t d F_{\text{tu}} = 1.5 (0.033")(0.332")(45,000 \text{ psi}) = 739 \text{ lb}$$

$$P_{\text{allow}} = 739 \text{ lb} / 3.0 = \underline{246 \text{ lb}}$$

Bearing Capacity (of #8 screw on frame)

$$P_b = F_e D t / K_D = (3,350 \text{ psi})(0.164")(1.00") / (10(0.164) + 0.5) = \underline{257 \text{ lb}}$$

Bearing Capacity (of #8 screw on strap anchor)

$$P_b = 2.7 D t F_{\text{tu}} = 2.7(0.164")(0.033")(45,000 \text{ psi}) = 657 \text{ lb}$$

$$P_{\text{allow}} = 657 \text{ lb} / 3.0 = \underline{219 \text{ lb}}$$

Design Capacity of the Connection = 197 lb (one screw)

Design Capacity of the Connection = 394 lb (two screws)

Anchorage Requirements

Series/Model: Contours Steel Wood Edge Inswing/Outswing Glazed XX
Test Unit Size: 74" x 81-3/4" & 74" x 82-1/2"
Design Pressure: +60.0 / -65.0 psf (74" x 82-1/2")
+65.0 / -60.0 psf (74" x 81-3/4")

Through-Frame Installation Method

Through frame installation method is validated by the test

Through Frame Anchor Capacity = 111 lb / anchor

Alternate Installation Methods

Strap Anchor to Wood = 122 lb / anchor

Through-Frame to Concrete = 181 lb / anchor

Through-Frame to CMU Block = 135 lb / anchor

Strap Anchor to Concrete = 181 lb / anchor

Strap Anchor to CMU Block = 135 lb / anchor

Strap Anchor to Wood (Cap Installation) = 197 lb / anchor

Minimum Alternate Installation Capacity = 122 lb / anchor

122 lb > 111 lb

Alternate Anchorages OK at tested spacing



Project No.: 27561.04-107-16
Project Name: Contours Steel Wood Edge
Inswing/Outswing Glazed XX
Date: 4/23/2024

Revision Log

Rev. #	Date	Page(s)	Revision(s)
0	11/17/2023	All	Original Report Issue
1	2/1/2024	All	Added Table 2 for the Plastic Checklist test results
2	4/23/2024	Page 5	Updated Table 2