

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511005B

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
FT Myers, FL 33912

Product Line: 2561 Double Hung Window

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-00620 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test Report No.: CTLA-2062W-7 signed and sealed by Ramesh Patel, P.E.
Certified Testing Laboratories, Orlando, FL.
ASTM E1886/ E1996 Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Load Test, ± 50.0 psf design pressure
3. Test Report No.: ATI 77631.06-501-47 signed by Lynn George
Architectural Testing, Springdale, PA.
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 50.16 psf
Water penetration resistance 7.52 psf
4. Anchor calculations, report number 511005-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 50.0 psf
- Maximum unit size: 48" x 72"
- Units must be glazed per ASTM E 1300 see installation instructions for glass details.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- PVC profiles certified by AAMA Deceunick North America DEP-1 and VBP-2

Installation:

Units must be installed in accordance with approval document, 08-00620 Revision B.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

