L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688 0609 rllomas@lrlomaspe.com

Report No.: 510945B

Manufacturer: Eastern Architectural Systems

16341 Domestic Ave. FT Myers, FL 33912

Product Line: Series 1431 Vinyl Single Hung Window

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

- Approval document: drawing number 08-00556 Revision C, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Report No.: 66892.07-109-47/66896.07-109-47 signed and sealed by Michael D. Stremmel, P.E.

Architectural Testing Inc., York, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±50.0psf
Water penetration resistance 7.50psf

Anchor calculations and comparative analysis, report number 510945-1C, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

Design pressure: ±50.0psf

Unit size: 47 1/2" x 71 1/2"
 Units must be glazed per ASTM E1300.

- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-00556 Revision C.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

* No. 6251# *

No. 6251# *

No. 6251# *

STATE OF WILLIAM

ONAL ENGINEER

NO. 6251#

NO.

Luis R. Lomas, P.E. FL No.: 62514 04/26/2021