L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd.
Lewisville, NC 27023 **Report No.: 510947C**434-688-0609

Manufacturer: Eastern Architectural Systems

16341 Domestic Ave. Ft Myers, FL 33912

Product Line: Series 1441 Vinyl Single Hung Window, Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

- Approval document: drawing number 08-00558 Revision D, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test Report No.: ATI 66896.07-109-47-R1 signed by Michael L. Mackereth

Architectural Testing, York, PA. AAMA/WDMA/CSA 101/I.S.2/A440

Design pressure: ±50.0psf Water penetration resistance 7.5psf

3. Anchor calculations and comparative analysis report number 510947-1C, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

Design pressure: ±50.0psf
 Unit size: 53 1/2" x 72"

- Units may be per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- PVC profiles certified by AAMA Deceunick North America DEP-1 and VBP-2

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-00558 Revision D.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

* No. 62514 *

No. 62514 *

STATE OF WILLIAM

ONAL ENGINEER

ONAL

Luis R. Lomas, P.E. FL No.: 62514 04/28/2021