L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 512353B

Manufacturer: Eastern Architectural Systems

16341 Domestic Ave. FT Myers, FL 33912

Product Line: Series 623 Vinyl Sliding Glass Door, OXO 144" X 96" Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

- Approval document: drawing number 08-01673 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Report No.: ESP009160P-6 signed and sealed by Ramesh Patel P.E.

Element Materials Technology, Wausau, WI

AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±50.0psf
Water penetration resistance 7.5psf

3. Report No.: ESP009160P-8 signed and sealed by Ramesh Patel P.E.

Element Materials Technology, Wausau, WI

AAMA/WDMA/CSA 101/1.S.2/A440

Design Pressure: ±50.0psf Water penetration resistance: 7.5psf

4. Anchor calculations, report number 512353-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

Maximum design pressure: ±50.0psf
Maximum unit size: ±4" x 96"


- Units must be glazed per ASTM E 1300 with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with approval document, 08-01673 Revision A.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 10/19/2020