

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609

Engineering Evaluation Report

Report No.: 513443A

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Fort Myers, FL 33912

Product Line: Series 135° FD8100 Aluminum Sliding Glass Pocket Door

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02668, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test Report No.: NCTL 210-3757-1A signed and sealed by Gerard J. Ferrara, P.E.
National Certified Testing Laboratories, Orlando, FL
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±50.0psf
Water resistance: 9.0psf
3. Test report No.: NCTL 210-3757-1 signed and sealed by Gerard J. Ferrara, P.E.
National Certified Testing Laboratories, Orlando, FL
TAS 202 Uniform Static Air Pressure, ±50.0psf design pressure, 9.0psf water penetration.
4. Anchor calculations, report number 513443-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ±50.0 psf
- Maximum panel size: 49 1/2" x 118 1/32"
- Units must be glazed per ASTM E1300
- This product is rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T6

Installation:

Units must be installed in accordance with approval document, 08-02668.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

