1432 Woodford Rd. Lewisville, NC 27023 434-688-0609

Engineering Evaluation Report

Report No.: 513448C

Manufacturer: Eastern Architectural Systems 16341 Domestic Ave. Fort Myers, FL 33912

Product Line: Series FD8100 Aluminum Sliding Glass Door - Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-02673, revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: NCTL 210-3407-1 signed and sealed by Gerard J. Ferrara, P.E.
 - National Certified Testing Laboratories, Orlando, FL

 TAS 201
 Large Missile Impact Test, Level D, Wind Zone 4

 TAS 202
 Uniform Static Air Pressure, +100.0/-110.0psf design pressure, 15.0psf water penetration.

 Water resistance:
 With 1.675" Sill Riser = 6.0psf

 With 2.675" Sill Riser = 10.45psf
 With 3.675" Sill Riser = 15.0psf

 TAS 203
 Cyclic Pressure loading +100.0/-110.0psf design pressure
- 3. Anchor calculations, report number 513448-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:


- Maximum design pressure: Refer to installation instructions.
- Maximum panel size: 49 1/2" x 106 1/4"
- Units must be glazed per ASTM E1300 according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T6

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02673, revision B.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 10/19/2020