

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609

Engineering Evaluation Report

Report No.: 511113B

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave
Ft. Myers, FL 33912

Product Line: Series 1641 Vinyl Casement Window - Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-00700 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test Report No.: ATI 69765.05-109-47/66570.01-701-47 signed by Stephen D. Shark
Architectural Testing, York, PA.
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 50.0 psf
Water penetration resistance 9.75psf
3. Anchor calculations, report number 511113-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 50.0 psf
- Maximum unit size: 37" x 75"
- Units must be glazed per ASTM E1300
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- PVC profiles certified by AAMA Deceunick North America DEP-1 and VBP-2

Installation:

Units must be installed in accordance with approval document, 08-00700 Revision B.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

