

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511793C

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Ft. Myers, FL 33912

Product Line: Series 3241 HR PVC Horizontal Sliding Window – Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code

Supporting Technical Documentation:

1. Approval document: drawing number 08-01214 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: ATI 99101.04-501-47 signed by Lynn George.
Architectural Testing, Springdale, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±50.16psf
Water penetration resistance 8.36psf
3. Anchor calculation, report number 511793-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ±50.0psf
- Maximum unit size: 71 1/2" x 59 1/2"
- Approved configurations: XO, OX
- Units must be glazed per ASTM E1300
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame and sash material to be extruded rigid PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-01214 Revision B.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

